

 EZY CHEK SYSTEMS LEAK DETECTOR TEST 316 W. Indiana Ave. Chesterton, IN 46304 REVISION 8/21/2019				DATE AND TIME		11/14/2023 - 10:00-12:10		
				WEATHER		40 Cloudy		
				COLLECT/INVOICE		Collected		
				CLIENT EMAIL		-		
				Testing Company Information				
Test Location Information				Certifications		Name		Midwest Tank Testing
PC # and WO #				Estabrooks: 82-1906		Address		316 W. Indiana Ave.
Name and FID #		Marathon - FID 5394		ICC: 10221928		City/State/Zip		Chesterton, IN 46304
Address		2701 Prairie St.		Indiana: UC 110386		Phone		800-975-1436
City/State/Zip		Elkhart, IN 46517		CP/STI: 16655		Technician Information		
Contact				UC111023		Name		Chris Zell
Phone						Email		support@midwesttanktesting.com
TYPE OF LEAK DETECTOR - (LD) or (ELD)								
PUMP #	PRODUCT			MODEL		SERIAL # (If Legible)		
1	Regular			FX1V		N/A		
2	Premium			FePetro		N/A		
3	Diesel			FePetro		N/A		
4								
5								
6								
7								
8								
LEAK DETECTOR TEST								
PUMP #	Product Type	Metering Pressure	Functional Element Holding PSI	Resiliency	Test Leak Rate ML/MIN	Opening Time	Results	
1	Regular	30	27	430	189ml	4	Pass	
2	Premium	27	12	110	189ml	2	Pass	
3	Diesel	33	20	150	189ml	4	Pass	
4					189ml			
5					189ml			
6					189ml			
7					189ml			
8					189 ml			
COMMENTS/RECOMMENDATIONS:								



AN ENVIRONMENTAL COMPLIANCE COMPANY
316 W. Indiana Ave.
Chesterton, IN 46304

EZY CHEK SYSTEMS

PRODUCT LINE TEST

DATE AND TIME

11/14/2023 - 10:00-12:10

Test Location Information

PC # and WO #	
Name and FID #	Marathon - FID 5394
Address	2701 Prairie St.
City/State/Zip	Elkhart, IN 46517
Contact	
Phone	

Testing Company Information

Name	Midwest Tank Testing
Address	316 W. Indiana Ave.
City/State/Zip	Chesterton, IN 46304
Phone	800-975-1436

Technician Information

Name	Chris Zell
Email	support@midwesttanktesting.com
Applied Pressure	1-1/2 Times Working Pressure, Min 50 PSI

PRODUCT LINE TEST - DATA (LT)

#1	Product Type:		Regular			
TIME	DATA	-/+	GPL	RES	GPH	
10:20	80	0	0.0037	0.0000	0.0000	
10:35	80	0	0.0037	0.0000	0.0000	
10:50	80	0	0.0037	0.0000	0.0000	
11:05	80	0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
FINAL RESULT:			Pass			

#2	Product Type:		Premium			
TIME	DATA	-/+	GPL	RES	GPH	
10:20	90	0	0.0037	0.0000	0.0000	
10:35	90	0	0.0037	0.0000	0.0000	
10:50	90	0	0.0037	0.0000	0.0000	
11:05	90	0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
FINAL RESULT:			Pass			

#3	Product Type:		Diesel			
TIME	DATA	-/+	GPL	RES	GPH	
10:20	70	0	0.0037	0.0000	0.0000	
10:35	70	0	0.0037	0.0000	0.0000	
10:50	70	0	0.0037	0.0000	0.0000	
11:05	70	0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
FINAL RESULT:			Pass			

#4	Product Type:					
TIME	DATA	-/+	GPL	RES	GPH	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
FINAL RESULT:						

#5	Product Type:					
TIME	DATA	-/+	GPL	RES	GPH	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
FINAL RESULT:						

#6	Product Type:					
TIME	DATA	-/+	GPL	RES	GPH	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
		0	0.0037	0.0000	0.0000	
FINAL RESULT:						

COMMENTS/RECOMMENDATIONS: Reg, Prem, DSL shut off ball valves and functioning element screws need repaired.



INDIANA HOMELAND SECURITY



Underground Storage Tank

CHRIS ZELL
316 W INDIANA AVE
CHESTERTON, INDIANA

STATE/PERMIT #
UC111987

ISSUE
12/29/2022

EFFECTIVE
12/30/2022

EXPIRATION
12/29/2024

DISCIPLINES

☒ Installation or Retrofitting

☐ Decommissioning Closure

☐ Cathodic Protection

☐ Decommissioning Removal

☐ Testing

The attached testing was completed at this site by an IDHS certified technician.

Technician's Signature: _____

Chris Zell


Midwest Tank Testing
AN ENVIRONMENTAL COMPLIANCE COMPANY

316 W. Indiana Ave.
Chesterton, IN 46304
(800) 975-1436

Serving the Midwest Since 1990