

Handy Spot
2701 Prairie Ave
Elkhart, IN 46517

09/05/2023 2:00 PM

SCALD TEST REPORT

UNLEAD 10140.0 GAL
UNLEAD

LEAK TEST 0.200 GPH
LEAK THRESHOLD 0.100 GPH
INTERVAL 18.0
UOL QUALIFY 0.0%
TEST STARTED 11:57 PM
TEST STARTED 09/04/2023
STATUS 1000.02
TEST ENDED 2:18 AM
TEST ENDED 09/05/2023

SLOPE -0.017 GAL/HR
TEST RESULT PASSED
SLOPE EQUALS CALCULATED
LEAK RATE

DIESEL 10140.0 GAL
PREMIUM

LEAK TEST 0.200 GPH
LEAK THRESHOLD 0.100 GPH
INTERVAL 18.0
UOL QUALIFY 0.0%
TEST STARTED 11:07 AM
TEST STARTED 09/05/2023
STATUS 2000.02
TEST ENDED 2:00 PM
TEST ENDED 09/05/2023

SLOPE 0.063 GAL/HR
TEST RESULT PASSED
SLOPE EQUALS CALCULATED
LEAK RATE

PREMIUM 10140.0 GAL
DIESEL

LEAK TEST 0.200 GPH
LEAK THRESHOLD 0.100 GPH
INTERVAL 18.0
UOL QUALIFY 0.0%
TEST STARTED 9:29 AM
TEST STARTED 09/05/2023
STATUS 0.02
TEST ENDED 12:07 PM
TEST ENDED 09/05/2023

SLOPE 0.016 GAL/HR
TEST RESULT PASSED
SLOPE EQUALS CALCULATED
LEAK RATE

Handy Spot
2701 Prairie Ave
Elkhart, IN 46517

09/05/2023 2:01 PM

LEAK ESTIMATE REPORT

UNLEAD

LEAK TEST 0.200 GPH
CONFIDENCE LEVEL 90.0%
GROSS CAPACITY 59.3%
GROSS 6002.0 GAL
NET 5949.3 GAL
LEVEL 54.755 IN
TEMP 72.464 F
WATER UOL 13.6 GAL
WATER LEVEL 0.637 IN
EST TIME 5 HRS 5 MIN

DIESEL