

Handy Spot
2701 Prairie Ave
Elkhart, IN 46517

06/09/2024

4:12 PM

LEAK TEST REPORT

AD 10140.0 GAL

UNLEAD

ME 2:00 AM
END DATE 06/21/2018
RESULT ABORTED
REASON 130066

L 10140.0 GAL

PREMIUM

ST 0.200 GPH
LEAK THRESHOLD 0.100 GPH
DENCE LEVEL 90.0%
TEST STARTED 1:00 AM
TARTED 06/26/2018
END TIME 3:00 AM
06/26/2018

LEVEL 23.4 IN
1916.5 GAL
TEMP 67.2 F
ULT INCOMPLETE
REASON MAX TIME

M 10140.0 GAL

DIESEL

TEST 0.200 GPH
LEAK THRESHOLD 0.100 GPH
CE LEVEL 90.0%
TEST STARTED 1:00 AM
ARTED 06/26/2018
END TIME 3:00 AM
06/26/2018

LEVEL 23.8 IN
1978.9 GAL
TEMP 68.0 F
RESULT INCOMPLETE
REASON MAX TIME

Hardy (not
2701 Prairie Ave
Elkhart, IN 46517

06/09/2024 4:13 PM

SCALD TEST REPORT

10140.0 GAL
UNLEAD

LEAK TEST 0.200 GPH
LEAK THRESHOLD 0.100 GPH
INTERVAL 18.0
VOL QUALIFY 0.0%
TEST STARTED 4:43 AM
TEST STARTED 06/09/2024
STATUS 0.02
TEST ENDED 7:48 AM
TEST ENDED 06/09/2024

SLOPE 0.039 GAL/HR
RESULT PASSED
SLOPE EQUALS CALCULATED
LEAK RATE

DIESEL 10140.0 GAL
PREMIUM

LEAK TEST 0.100 GPH
LEAK THRESHOLD 0.100 GPH
INTERVAL 18.0
VOL QUALIFY 0.0%
TEST STARTED 11:59 AM
TEST STARTED 06/09/2024
STATUS 1.00
TEST ENDED 2:51 PM
TEST ENDED 06/09/2024

0.009 GAL/HR
TEST RESULT PASSED
SLOPE EQUALS CALCULATED
LEAK RATE

PREMIUM 10140.0 GAL
DIESEL

LEAK TEST 0.200 GPH
LEAK THRESHOLD 0.100 GPH
INTERVAL 18.0
VOL QUALIFY 1.01
TEST STARTED 10:37 AM
TEST STARTED 06/09/2024
STATUS 0.02
TEST ENDED 1:33 PM
TEST ENDED 06/09/2024

SLOPE -0.023 GAL/HR
TEST RESULT PASSED
SLOPE EQUALS CALCULATED
LEAK RATE