

Handy Spot
2701 Prairie Ave
Elkhart, IN 46517

11/28/2024

5:21 PM

REGULATORY REPORT

HARDWARE STATUS

TS-CIM	NOT INSTALLED
TS-ROM	NOT INSTALLED
TS-SEM 1	NOT INSTALLED
TS-SEM 2	NOT INSTALLED
TS-CPM	NOT INSTALLED
PRINTER	OPERATIONAL
FAX/MOD	OPERATIONAL

PROBES

PROBE 1	OPERATIONAL
PROBE 2	OPERATIONAL
PROBE 3	OPERATIONAL

AUXILIARY INPUTS

AUX IN 1	OPERATIONAL
AUX IN 2	OPERATIONAL

PASSED LEAK TESTS

TANK 1

NO DATA

TANK 2

04/17/2018	4:34 AM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH

TANK 3

04/16/2018	3:03 AM
LEAK TEST	0.10 GPH
SLOPE	0.00 GPH

PASSED SCALD TESTS

TANK 1

11/26/2024	3:09 AM
LEAK TEST	0.20 GPH
SLOPE	-0.01 GPH

11/24/2024	9:48 PM
LEAK TEST	0.20 GPH
SLOPE	-0.06 GPH

10/25/2024	2:39 AM
LEAK TEST	0.20 GPH
SLOPE	-0.09 GPH

09/25/2024	11:09 PM
LEAK TEST	0.20 GPH
SLOPE	-0.08 GPH

08/26/2024	3:12 AM
LEAK TEST	0.20 GPH
SLOPE	-0.07 GPH

07/27/2024	1:35 AM
LEAK TEST	0.20 GPH
SLOPE	-0.07 GPH

06/27/2024	1:27 AM
LEAK TEST	0.20 GPH
SLOPE	0.04 GPH

05/29/2024	2:56 AM
LEAK TEST	0.20 GPH
SLOPE	-0.04 GPH

04/30/2024	11:47 PM
LEAK TEST	0.20 GPH
SLOPE	-0.03 GPH

03/31/2024	11:08 PM
LEAK TEST	0.20 GPH
SLOPE	0.03 GPH

03/01/2024	6:28 AM
LEAK TEST	0.20 GPH
SLOPE	-0.03 GPH

01/31/2024	3:06 AM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH

01/01/2024	11:51 PM
LEAK TEST	0.20 GPH
SLOPE	0.02 GPH

12/02/2023	4:00 AM
LEAK TEST	0.20 GPH
SLOPE	0.00 GPH

11/02/2023	3:20 AM
LEAK TEST	0.20 GPH
SLOPE	-0.05 GPH

TANK 2

11/28/2024	4:26 PM
LEAK TEST	0.20 GPH
SLOPE	0.00 GPH
11/21/2024	10:46 PM
LEAK TEST	0.20 GPH
SLOPE	-0.02 GPH
10/22/2024	11:08 PM
LEAK TEST	0.20 GPH
SLOPE	-0.01 GPH
09/22/2024	10:44 PM
LEAK TEST	0.20 GPH
SLOPE	-0.01 GPH
08/23/2024	11:48 PM
LEAK TEST	0.20 GPH
SLOPE	0.02 GPH
07/24/2024	10:35 PM
LEAK TEST	0.20 GPH
SLOPE	0.05 GPH
06/24/2024	10:22 PM
LEAK TEST	0.20 GPH
SLOPE	0.03 GPH
05/25/2024	10:28 PM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH
04/25/2024	10:11 PM
LEAK TEST	0.20 GPH
SLOPE	-0.02 GPH
03/26/2024	10:35 PM
LEAK TEST	0.20 GPH
SLOPE	-0.04 GPH
02/25/2024	10:12 PM
LEAK TEST	0.20 GPH
SLOPE	-0.01 GPH
01/26/2024	11:11 PM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH
12/27/2023	11:57 PM
LEAK TEST	0.20 GPH
SLOPE	0.00 GPH
11/27/2023	11:51 PM
LEAK TEST	0.20 GPH
SLOPE	-0.01 GPH

TANK 3

11/28/2024	2:46 PM
LEAK TEST	0.20 GPH
SLOPE	-0.01 GPH
11/20/2024	11:11 PM
LEAK TEST	0.20 GPH
SLOPE	0.03 GPH
10/21/2024	9:58 PM
LEAK TEST	0.20 GPH
SLOPE	-0.01 GPH
09/21/2024	11:49 PM
LEAK TEST	0.20 GPH
SLOPE	-0.01 GPH
08/22/2024	11:12 PM
LEAK TEST	0.20 GPH
SLOPE	-0.01 GPH
07/23/2024	11:16 PM
LEAK TEST	0.20 GPH
SLOPE	0.05 GPH
06/23/2024	10:20 PM
LEAK TEST	0.20 GPH
SLOPE	-0.01 GPH
05/24/2024	8:47 PM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH
04/24/2024	10:41 PM
LEAK TEST	0.20 GPH
SLOPE	-0.01 GPH
03/25/2024	11:24 PM
LEAK TEST	0.20 GPH
SLOPE	0.02 GPH
02/24/2024	7:22 PM
LEAK TEST	0.20 GPH
SLOPE	0.03 GPH
01/25/2024	11:50 PM
LEAK TEST	0.20 GPH
SLOPE	0.00 GPH
12/26/2023	7:06 PM
LEAK TEST	0.20 GPH
SLOPE	0.08 GPH
11/26/2023	11:48 PM
LEAK TEST	0.20 GPH
SLOPE	-0.01 GPH