

Handy Spot
2701 Prairie Ave
Elkhart, IN 46517
07/14/2024 6:29 PM

LEAK TEST REPORT

UNLEAD 10140.0 GAL
UNLEAD

END TIME 2:00 AM
END DATE 06/26/2018
TEST RESULT ABORTED
REASON DISPENSE

DIESEL 10140.0 GAL

PREMIUM

LEAK TEST 0.200 GPH
LEAK THRESHOLD 0.100 GPH
CONFIDENCE LEVEL 90.0%
TEST STARTED 1:00 AM
TEST STARTED 06/26/2018
END TIME 3:00 AM
END DATE 06/26/2018
LEVEL 23.4 IN
GROSS 1916.5 GAL
TEMP 67.2 F
TEST RESULT INCOMPLETE
REASON MAX TIME

PREMIUM 10140.0 GAL

DIESEL

LEAK TEST 0.200 GPH
LEAK THRESHOLD 0.100 GPH
CONFIDENCE LEVEL 90.0%
TEST STARTED 1:00 AM
TEST STARTED 06/26/2018
END TIME 3:00 AM
END DATE 06/26/2018
LEVEL 23.8 IN
GROSS 1978.9 GAL
TEMP 68.0 F
TEST RESULT INCOMPLETE
REASON MAX TIME

Handy Spot
2701 Prairie Ave
Elkhart, IN 46517
07/14/2024 6:29 PM

SCALD TEST REPORT

UNLEAD 10140.0 GAL
UNLEAD

LEAK TEST 0.200 GPH
LEAK THRESHOLD 0.100 GPH
INTERVAL 18.0
UOL QUALIFY 0.0%
TEST STARTED 3:22 AM
TEST STARTED 07/14/2024
STATUS 1000.02
TEST ENDED 6:23 AM
TEST ENDED 07/14/2024

SLOPE -0.057 GAL/HR
TEST RESULT PASSED
SLOPE EQUALS CALCULATED
LEAK RATE

DIESEL 10140.0 GAL
PREMIUM

LEAK TEST 0.200 GPH
LEAK THRESHOLD 0.100 GPH
INTERVAL 18.0
UOL QUALIFY 0.0%
TEST STARTED 3:27 PM
TEST STARTED 07/14/2024
STATUS 0.02
TEST ENDED 5:46 PM
TEST ENDED 07/14/2024

SLOPE -0.003 GAL/HR
TEST RESULT PASSED
SLOPE EQUALS CALCULATED
LEAK RATE

PREMIUM 10140.0 GAL
DIESEL

LEAK TEST 0.200 GPH
LEAK THRESHOLD 0.100 GPH
INTERVAL 18.0
UOL QUALIFY 0.0%
TEST STARTED 12:47 PM
TEST STARTED 07/14/2024
STATUS 0.02
TEST ENDED 4:11 PM
TEST ENDED 07/14/2024

SLOPE 0.006 GAL/HR
TEST RESULT PASSED