

[illegible]

12/24/2024	0.07
LEAK TEST	4:46 AM
SLOPE	0.20 GPH
11/24/2024	-0.05 GPH
LEAK TEST	9:48 PM
SLOPE	0.20 GPH
10/25/2024	-0.06 GPH
LEAK TEST	2:39 AM
SLOPE	0.20 GPH
09/25/2024	-0.09 GPH
LEAK TEST	11:09 PM
SLOPE	0.20 GPH
09/29/2025	-0.08 GPH
LEAK TEST	4:45 PM
SLOPE	0.20 GPH
09/17/2025	-0.02 GPH
LEAK TEST	10:55 PM
SLOPE	0.20 GPH
08/18/2025	-0.02 GPH
LEAK TEST	11:50 PM
SLOPE	0.20 GPH
07/19/2025	0.00 GPH
LEAK TEST	10:38 PM
SLOPE	0.20 GPH
06/19/2025	0.04 GPH
LEAK TEST	10:43 PM
SLOPE	0.20 GPH
05/20/2025	-0.04 GPH
LEAK TEST	11:41 PM
SLOPE	0.20 GPH
04/20/2025	0.01 GPH
LEAK TEST	11:21 PM
SLOPE	0.20 GPH
03/21/2025	0.00 GPH
LEAK TEST	11:19 PM
SLOPE	0.20 GPH
02/19/2025	-0.00 GPH
LEAK TEST	11:36 PM
SLOPE	0.20 GPH
01/20/2025	0.01 GPH
LEAK TEST	9:46 PM
SLOPE	0.20 GPH
12/21/2024	0.04 GPH
LEAK TEST	11:28 PM
SLOPE	0.20 GPH
11/21/2024	-0.02 GPH
LEAK TEST	10:46 PM
SLOPE	0.20 GPH
10/22/2024	-0.02 GPH
LEAK TEST	11:08 PM
SLOPE	0.20 GPH
09/22/2024	-0.01 GPH
LEAK TEST	10:44 PM
SLOPE	0.20 GPH

TANK 3

09/29/2025	4:35 PM
LEAK TEST	0.20 GPH
SLOPE	0.03 GPH
09/16/2025	10:07 PM
LEAK TEST	0.20 GPH
SLOPE	-0.03 GPH
08/17/2025	10:51 PM
LEAK TEST	0.20 GPH
SLOPE	-0.10 GPH
07/18/2025	10:50 PM
LEAK TEST	0.20 GPH
SLOPE	-0.00 GPH
06/18/2025	10:15 PM
LEAK TEST	0.20 GPH
SLOPE	0.03 GPH
05/19/2025	11:33 PM
LEAK TEST	0.20 GPH
SLOPE	-0.00 GPH
04/19/2025	10:10 PM
LEAK TEST	0.20 GPH
SLOPE	-0.06 GPH
03/20/2025	11:43 PM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH
02/18/2025	10:58 PM
LEAK TEST	0.20 GPH
SLOPE	-0.01 GPH
01/19/2025	10:41 PM
LEAK TEST	0.20 GPH
SLOPE	-0.03 GPH
12/20/2024	11:40 PM
LEAK TEST	0.20 GPH
SLOPE	0.01 GPH
11/20/2024	11:11 PM
LEAK TEST	0.20 GPH
SLOPE	0.03 GPH
10/21/2024	9:58 PM
LEAK TEST	0.20 GPH
SLOPE	-0.01 GPH
09/21/2024	11:49 PM
LEAK TEST	0.20 GPH
SLOPE	-0.01 GPH