

Tanks Data

30 DAYS WALK THROUGH INSPECTION

UST Facility I.D. (FID) #	S394	Contact Number	
Facility Name	Mohit	Contact email	
Address	2701 Prairie St, Elkhart,	Date of Inspection	04-27-24
Operator on Duty Name	JN-46517	Name of the Person Conducting Inspection	Mohit Singh

Operator Training		Registration/Notification Form		Release Detection	
Operator Training current	Registration/Notification Form	Release Detection	Operator Notified	Operator Notified	Operator Notified
☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No	☐ Yes ☐ No
Is Registration current with correct owner, operator etc.					
Release Detection Method					
Make and Model	ATG	ICM	BIR	IC	Other
Does it have paper?	Yes	No	Operator Notified	Yes	No
Is it in Alarm mode?	Yes	No	Operator Notified	Yes	No
Interstitial Monitoring Sensor Status Normal	Yes	No	Operator Notified	Yes	No
Necessary Monthly Printout Taken	Yes	No	Operator Notified	Yes	No

Spill Buckets		Fill Ports		Piping/STP Sumps		Under Dispenser Containments (UDC)	
Are Spill Buckets Clean and free from water, debris, product etc?	Are the Spill Bucket in good condition and free of damage/cracks	Is Fill pipe cap tight and fill pipe free from any obstruction?	Are Sumps Clean and free from water, debris, product etc?	Are UDCs clean and free from water, debris, product etc?	Operator Notified	Operator Notified	Operator Notified
Yes	Yes	Yes	Yes	Yes	Operator Notified	Operator Notified	Operator Notified
No	No	No	No	No	Operator Notified	Operator Notified	Operator Notified

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name: _____ Signature: _____ Date: _____

317-645-0215 tanksdata@gmail.com www.tanksdata.com