

Tanks Data		30 DAYS WALK THROUGH INSPECTION	
UST Facility I.D. (FID) # 16738		Contact Number	
Facility Name Marathon		Contact email	
Address 13060 Jefferson Blvd Mishawaka		Date of Inspection 9/2/22	
Operator on Duty Name 46545		Name of the Person Conducting Inspection Josh Rider	
Operator Training		Operator Notified	
Operator Training current	☒ Yes ☐ No	☐ Yes ☐ No	
Registration/Notification Form		Operator Notified	
Is Registration current with correct owner, operator etc.	☐ Yes ☐ No	☐ Yes ☐ No	
Release Detection		Operator Notified	
Release Detection Method	☒ ATG ☐ CIM	☐ SIR ☐ C ☐ Other	
Make and Model	VR TLS-450 Plus	Operator Notified	☐ Yes ☐ No
Does it have paper?	☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Is it in Alarm mode?	☐ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Interstitial Monitoring Sensor Status Normal	☐ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Necessary Monthly Printout Taken	☐ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Spill Buckets		Operator Notified	
Are Spill Buckets Clean and free from water, debris, product etc?	☐ Yes ☒ No	☒ Yes ☐ No	
Are the Spill Bucket in good condition and free of damage/cracks	☒ Yes ☐ No	Operator Notified	☐ Yes ☐ No
Fill Ports		Operator Notified	
Is Fill pipe cap tight and fill pipe free from any obstruction?	☒ Yes ☐ No	☐ Yes ☐ No	
Piping/STP Sumps		Operator Notified	
Are Sumps Clean and free from water, debris, product etc?	☐ Yes ☒ No	☒ Yes ☐ No	
Under Dispenser Containments (UDC)		Operator Notified	
Are UDCs clean and free from water, debris, product etc?	☐ Yes ☒ No	☒ Yes ☐ No	
NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.			
Operator on Duty Name		Date	
317-645-0215		www.tanksdata.com	
tanksdata@gmail.com		20220516	

= UST Periodic Test
 DURS = 31
 VG. VOLUME = 8173
 VOLUME = 67.9

9/02/22 1:28 PM
 42568 GPM #5639
 3060 E. JEFFERSON
 MISHAWAKA, IN 46545
 74-258-0021

Sensor Status Report -
 11 Sensors
 0 DATA AVAILABLE

9/02/22 1:28 PM
 42568 GPM #5639
 3060 E. JEFFERSON
 MISHAWAKA, IN 46545
 74-258-0021

PRESSURE LINE LEAK REPORTS
 ASSESSED TESTS HISTORY
 1: UNLEAD 1-4
 2: PREM
 3: UNLD 5-8