

7/05/24 4:24 PM

12568 GPM #5639
8060 E. JEFFERSON
SHAWAKA, IN 46545
74-258-0021

RESSURE LINE LEAK REPORTS
SSED TESTS HISTORY

1: UNLEAD 1-4

2: PREM

3: UNLD 5-8

7/05/24 4:24 PM

12568 GPM #5639
8060 E. JEFFERSON
SHAWAKA, IN 46545
74-258-0021

Sensor Status Report -
All Sensors

NO DATA AVAILABLE

7/05/24 4:24 PM

12568 GPM #5639
8060 E. JEFFERSON
SHAWAKA, IN 46545
74-258-0021

ANK LEAK TEST HISTORY -
SSED TEST RESULTS

1: UNLEAD

REPORT TYPE = LAST GROSS
DATE/TIME = 07/05/24 15:40
METHOD = SLD Gross Test
G. VOLUME = 1786
VOLUME = 14.8

REPORT TYPE = LAST PERIODIC
DATE/TIME = 07/05/24 7:09
METHOD = CSLD Periodic Test
DURS = 29
G. VOLUME = 2941
VOLUME = 24.4

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 07/02/24 6:42
METHOD = CSLD Periodic Test
DURS = 27
G. VOLUME = 2949
VOLUME = 24.5

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 06/01/24 23:00
METHOD = CSLD Periodic Test
DURS = 33
G. VOLUME = 4638
VOLUME = 38.5

... FULLEST PERIODIC ...