

5/03/24 3:26 PM

42568 GPM #5639
3060 E. JEFFERSON
SHAWAKA, IN 46545
74-258-0021

PRESSURE LINE LEAK REPORTS
PASSED TESTS HISTORY

1 1: UNLEAD 1-4

1 2: PREM

1 3: UNLD 5-8

5/03/24 3:27 PM

42568 GPM #5639
3060 E. JEFFERSON
SHAWAKA, IN 46545
74-258-0021

Sensor Status Report -
All Sensors

NO DATA AVAILABLE

06/03/24 3:27 PM

2568 GPM #5639
060 E. JEFFERSON
SHAWAKA, IN 46545
4-258-0021

NK LEAK TEST HISTORY -
TESTED TEST RESULTS

1: UNLEAD

PORT TYPE = LAST GROSS
DATE/TIME = 06/03/24 10:34
METHOD = SLD Gross Test
GROSS VOLUME = 4050
VOLUME = 33.7

PORT TYPE = LAST PERIODIC
DATE/TIME = 06/03/24 4:48
METHOD = CSLD Periodic Test
DURATION = 34
GROSS VOLUME = 4283
VOLUME = 35.6

PORT TYPE = FULLEST PERIODIC
DATE/TIME = 06/01/24 23:00
METHOD = CSLD Periodic Test
DURATION = 33
GROSS VOLUME = 4638
VOLUME = 38.5

PORT TYPE = FULLEST PERIODIC
DATE/TIME = 05/22/24 2:25
METHOD = CSLD Periodic Test
DURATION = 35
GROSS VOLUME = 5289
VOLUME = 44.0

PORT TYPE = FULLEST PERIODIC
DATE/TIME = 04/01/24 1:59
METHOD = CSLD Periodic Test
DURATION = 31
GROSS VOLUME = 4933
VOLUME = 41.0

PORT TYPE = FULLEST PERIODIC
DATE/TIME = 03/30/24 0:53
METHOD = CSLD Periodic Test
DURATION = 28
GROSS VOLUME = 5806
VOLUME = 48.3

PORT TYPE = FULLEST PERIODIC
DATE/TIME = 02/15/24 3:07
METHOD = CSLD Periodic Test
DURATION = 34
GROSS VOLUME = 4937
VOLUME = 41.0

PORT TYPE = FULLEST PERIODIC
DATE/TIME = 01/01/24 2:00
METHOD = CSLD Periodic Test
DURATION = 33
GROSS VOLUME = 4588
VOLUME = 38.1

PORT TYPE = FULLEST PERIODIC