

07/24 3:51 PM

2568 GPM #5639
060 E. JEFFERSON
SHAWAKA, IN 46545
4-258-0021

RESSURE LINE LEAK REPORTS
ASSED TESTS HISTORY

1: UNLEAD 1-4

2: PREM

3: UNLD 5-8

07/24 3:51 PM

2568 GPM #5639
060 E. JEFFERSON
SHAWAKA, IN 46545
4-258-0021

ensor Status Report -
1 Sensors

DATA AVAILABLE

07/24 3:51 PM

2568 GPM #5639
060 E. JEFFERSON
SHAWAKA, IN 46545
4-258-0021

ANK LEAK TEST HISTORY -
ASSED TEST RESULTS

1: UNLEAD

REPORT TYPE = LAST GROSS
DATE/TIME = 08/07/24 4:21
METHOD = SLD Gross Test
DURS = 2519
G. VOLUME = 20.9
VOLUME

REPORT TYPE = LAST PERIODIC
DATE/TIME = 08/07/24 5:16
METHOD = CSLD Periodic Test
DURS = 36
G. VOLUME = 3321
VOLUME = 27.6

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 08/03/24 4:56
METHOD = CSLD Periodic Test
DURS = 39
G. VOLUME = 3582
VOLUME = 29.8

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 07/15/24 4:59
METHOD = CSLD Periodic Test
DURS = 30
G. VOLUME = 4317
VOLUME = 35.9

REPORT TYPE = FULLEST PERIODIC
DATE/TIME = 06/01/24 23:00
METHOD = CSLD Periodic Test