

000
Tanks Data

30 DAYS WALK THROUGH INSPECTION

UST Facility I.D. (FID) # 16738 Contact Number

Facility Name MARIETTA Contact email

Address 13060 Jefferson Blvd, Mishawaka Date of Inspection 06/03/24

Operator on Duty Name IN 46545 Name of the Person Conducting Inspection AK SHIT SMITHAN.

Operator Training current

Operator Training
☐ Yes ☐ No Operator Notified ☐ Yes ☐ No

Is Registration current with correct owner, operator etc.

Registration/Notification Form
☐ Yes ☐ No Operator Notified ☐ Yes ☐ No

Release Detection Method

Release Detection
☒ ATG ☐ TIM ☐ BIR ☐ IC ☐ Other

Make and Model

VR 725 450 PIVS

Does it have paper?

☒ Yes ☐ No Operator Notified ☐ Yes ☐ No

Is it in Alarm mode?

☒ Yes ☐ No Operator Notified ☐ Yes ☐ No

Interstitial Monitoring Sensor Status Normal

☐ Yes ☐ No Operator Notified ☐ Yes ☐ No

Necessary Monthly Printout Taken

☐ Yes ☐ No Operator Notified ☐ Yes ☐ No

Spill Buckets

☐ Yes ☒ No Operator Notified ☐ Yes ☐ No

Are Spill Buckets Clean and free from water, debris, product etc?

☐ Yes ☒ No Operator Notified ☐ Yes ☐ No

Are the Spill Bucket in good condition and free of damage/cracks

☐ Yes ☒ No Operator Notified ☐ Yes ☐ No

Fill Ports

☐ Yes ☒ No Operator Notified ☐ Yes ☐ No

Is Fill pipe cap tight and fill pipe free from any obstruction?

☒ Yes ☐ No Operator Notified ☐ Yes ☐ No

Pipeline/SIP Sumps

☐ Yes ☒ No Operator Notified ☐ Yes ☐ No

Are Sumps Clean and free from water, debris, product etc?

☐ Yes ☒ No Operator Notified ☐ Yes ☐ No

Under Dispenser Containments (UDC)

☐ Yes ☒ No Operator Notified ☐ Yes ☐ No

Are UDCs clean and free from water, debris, product etc?

☐ Yes ☒ No Operator Notified ☐ Yes ☐ No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name

Signature

Date

317-645-0215

tanksdata@gmail.com

www.tanksdata.com

20220516