



5296 Breakers Way, Carmel, IN 46033

 www.tanksdata.com
 tanksdata@gmail.com
 (317)-300-6065

Date 8/30/24

LEAK DETECTOR TEST(DATA SHEET)

Test Location Information

Name	FID 16738
Address	13060 Jefferson Blvd
City	Mishawakw
Phone	
Contact	

Technician Information

Name	Josh Rider
Cert #	UC202406986

TYPE OF LEAK DETECTOR

PRODUCT TYPE	MAKE	MODEL	SERIAL#
Reg 1	Red Jacket MLLD		
Reg 2	Red Jacket MLLD		
Prem	Red Jacket MLLD		

Pump #	PRODUCT TYPE	Pump Pressure	Functional Element Holding PSI	Resiliency	Test Leak Rate ML/MIN	Opening Time	Pass/Fail
1	Regular 1	25	14	120 ml	189ml	4 sec	Pass
2	Regular 2	27	15	140 ml	189ml	4 sec	Pass
3	Premium	26	14	110 ml	189ml	5 sec	Pass
4					189ml		.
5					189ml		.
6					189ml		.
7					189ml		.
8					189ml		.

Comment:

Technician Signature :

Josh Rider