

UST OVERFILL EQUIPMENT INSPECTION AUTOMATIC SHUTOFF DEVICE AND BALL FLOAT VALVE

Facility Name:	SM Marathon	Owner:	SM Marathon
Address:	13060 Jefferson Blvd	Address:	13060 Jefferson Blvd
City, State, Zip Code:	Mishawaka, IN 46545	City, State, Zip Code:	Mishawaka, IN 46545
Facility I.D. #:	16738	Phone #:	16738

This data sheet is for inspecting automatic shutoff devices and ball float valves. See PEI/RP1200 Section 7 for inspection procedures.

Product Grade	Regular 1	Regular 2	Premium	Diesel		
Tank Number	1	2	3	4		
Tank Volume, gallons	12,000	6,000	8,000	4,000		
Tank Diameter, inches	96					
Overfill Prevention Device Brand	OPW					
Type of Overfill Device	☐	☐	☐	☐	☐	☐

AUTOMATIC SHUTOFF DEVICE INSPECTION

1. Drop tube removed from tank?	Yes ☐	No ☐	No ☐	☐	☐	☐	☐
2. Drop tube and float mechanisms free of debris?	Yes ☐	☐	☐	☐	☐	☐	☐
3. Float moves freely without binding and poppet moves into flow path?	Yes ☐	☐	☐	☐	☐	☐	☐
4. Bypass valve in the drop tube open and free of blockage (if present)?	Yes ☐	☐	☐	☐	☐	☐	☐
5. Flapper adjusted to shut off flow at 95% capacity?*	Yes ☐	☐	☐	☐	☐	☐	☐
6. Is Ball Float Present?	☐	☐	☐	☐	☐	☐	☐
7. Measured Auto Shut-Off Level							

A "No" to any item in Lines 1-5 indicates a test failure.

BALL FLOAT VALVE INSPECTION

1. Tank top fittings vapor- tight and leak-free?	☐	☐	☐	☐	☐	☐	☐
2. Ball float cage free of debris?	☐	☐	☐	☐	☐	☐	☐
3. Ball free of holes and cracks and moves freely in cage?	☐	☐	☐	☐	☐	☐	☐
4. Vent hole in pipe open and near top of tank?	☐	☐	☐	☐	☐	☐	☐
5. Ball float pipe proper length to restrict flow at 90% capacity?*	☐	☐	☐	☐	☐	☐	☐
6. Ball Float removed from the tank?	☐	☐	☐	☐	☐	☐	☐
7. Ball Float Level							

A "No" to any item in Lines 1-5 indicates a test failure.

Test Results	Pass ☐	Fail ☐	Fail ☐	Fail ☐	☐	☐	☐
--------------	-------------------------------	-------------------------------	-------------------------------	-------------------------------	--------------------------	--------------------------	--------------------------

Comment: Regular 2 and premium drop tubes will not come out of the ground. Adaptor likely rusted onto riser. Diesel does not have any kind of overfill prevention that I could find. VFC shows an alarm for Diesel but I never saw or heard one.

* Use manufacturer's suggested procedure for determining if automatic shutoff device will shut off flow at 95% capacity.

** Use manufacturer's suggested procedure for determining if flow restriction device will restrict flow at 90% capacity.

Tester's Name : Josh Rider

Tester's Signature : 