

# Tanks Data

## 30 DAYS WALK THROUGH INSPECTION

|                                           |                                                          |
|-------------------------------------------|----------------------------------------------------------|
| UST Facility I.D.(FID) # <u>16738</u>     | Contact Number                                           |
| Facility Name <u>Myrdalson</u>            | Contact email                                            |
| Address <u>13060 Jefferson Blvd #1654</u> | Date of Inspection <u>09-29-2025</u>                     |
| Operator on Duty Name                     | Name of the Person Conducting Inspection <u>Buttress</u> |

|                                                                   |                                                                |                           |                                                               |
|-------------------------------------------------------------------|----------------------------------------------------------------|---------------------------|---------------------------------------------------------------|
| <b>Operator Training</b>                                          |                                                                |                           |                                                               |
| Operator Training current                                         | <input type="radio"/> Yes <input type="radio"/> No             | Operator Notified         | <input type="radio"/> Yes <input type="radio"/> No            |
| <b>Registration/Notification Form</b>                             |                                                                |                           |                                                               |
| Is Registration current with correct owner, operator etc.         | <input type="radio"/> Yes <input type="radio"/> No             | Operator Notified         | <input type="radio"/> Yes <input type="radio"/> No            |
| <b>Release Detection</b>                                          |                                                                |                           |                                                               |
| Release Detection Method                                          | <input checked="" type="radio"/> ATG <input type="radio"/> CIM | <input type="radio"/> SIR | <input type="radio"/> IC <input type="radio"/> Other          |
| Make and Model <u>LR TCS-40 Plus</u>                              |                                                                |                           |                                                               |
| Does it have paper?                                               | <input checked="" type="radio"/> Yes <input type="radio"/> No  | Operator Notified         | <input type="radio"/> Yes <input type="radio"/> No            |
| Is it in Alarm mode?                                              | <input checked="" type="radio"/> Yes <input type="radio"/> No  | Operator Notified         | <input type="radio"/> Yes <input type="radio"/> No            |
| Interstitial Monitoring Sensor Status Normal                      | <input checked="" type="radio"/> Yes <input type="radio"/> No  | Operator Notified         | <input type="radio"/> Yes <input type="radio"/> No            |
| Necessary Monthly Printout Taken                                  | <input checked="" type="radio"/> Yes <input type="radio"/> No  | Operator Notified         | <input type="radio"/> Yes <input type="radio"/> No            |
| <b>Spill Buckets</b>                                              |                                                                |                           |                                                               |
| Are Spill Buckets Clean and free from water, debris, product etc? | <input type="radio"/> Yes <input checked="" type="radio"/> No  | Operator Notified         | <input type="radio"/> Yes <input type="radio"/> No            |
| Are the Spill Bucket in good condition and free of damage/cracks  | <input checked="" type="radio"/> Yes <input type="radio"/> No  | Operator Notified         | <input type="radio"/> Yes <input type="radio"/> No            |
| <b>Fill Ports</b>                                                 |                                                                |                           |                                                               |
| Is Fill pipe cap tight and fill pipe free from any obstruction?   | <input type="radio"/> Yes <input type="radio"/> No             | Operator Notified         | <input type="radio"/> Yes <input type="radio"/> No            |
| <b>Piping/STP Sumps</b>                                           |                                                                |                           |                                                               |
| Are Sumps Clean and free from water, debris, product etc?         | <input type="radio"/> Yes <input checked="" type="radio"/> No  | Operator Notified         | <input checked="" type="radio"/> Yes <input type="radio"/> No |
| <b>Under Dispenser Containments (UDC)</b>                         |                                                                |                           |                                                               |
| Are UDCs clean and free from water, debris, product etc?          | <input type="radio"/> Yes <input checked="" type="radio"/> No  | Operator Notified         | <input checked="" type="radio"/> Yes <input type="radio"/> No |

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name

317-645-0215

Signature

tanksdata@gmail.com

Date

www.tanksdata.com