

Tanks Data

30 DAYS WALK THROUGH INSPECTION

UST Facility I.D. (FID) #	16738	Contact Number	
Facility Name	Matheson	Contact email	
Address	3060 Jefferson Blvd	Date of Inspection	03/23/25
Operator on Duty Name	Misra, Anirudh	Name of the Person Conducting Inspection	Anirudh

Operator Training current

Operator Training

Operator Notified

☐ Yes

☐ No

Is Registration current with correct owner, operator etc.

Registration/Notification Form

Operator Notified

☐ Yes

☐ No

Release Detection Method

Release Detection

Operator Notified

☐ Yes

☐ No

Make and Model

ATG

Operator Notified

☐ Yes

☐ No

Does it have paper?

☒ Yes

Operator Notified

☐ Yes

☐ No

Is it in Alarm mode?

☐ Yes

Operator Notified

☐ Yes

☐ No

Interstitial Monitoring Sensor Status Normal

☒ Yes

Operator Notified

☐ Yes

☐ No

Necessary Monthly Printout Taken

☐ Yes

Operator Notified

☐ Yes

☐ No

Spill Buckets

☒ Yes

Operator Notified

☐ Yes

☐ No

Are Spill Buckets Clean and free from water, debris, product etc?

☒ Yes

Operator Notified

☐ Yes

☐ No

Are the Spill Bucket in good condition and free of damage/cracks

☒ Yes

Operator Notified

☐ Yes

☐ No

Fill Ports

☒ Yes

Operator Notified

☐ Yes

☐ No

Is Fill pipe cap tight and fill pipe free from any obstruction?

☒ Yes

Operator Notified

☐ Yes

☐ No

Piping/STP Sumps

☒ Yes

Operator Notified

☐ Yes

☐ No

Are Sumps Clean and free from water, debris, product etc?

☒ Yes

Operator Notified

☐ Yes

☐ No

Under Dispenser Containments (UDC)

☒ Yes

Operator Notified

☐ Yes

☐ No

Are UDCs clean and free from water, debris, product etc?

☒ Yes

Operator Notified

☐ Yes

☐ No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name

Signature

Date

317-645-0215

tanksdata@gmail.com

www.tanksdata.com