

MARATHON 3107
335 W. MCKINLEY
MISAWAKA IN 46545

MAR 21, 2023 10:13 AM

CSLD TEST RESULTS

MAR 21, 2023 10:13 AM

T 1:REGULAR
PROBE SERIAL NUM 813581

0.2 GAL/HR TEST
PER: MAR 21, 2023 PASS

T 2:PREMIUM
PROBE SERIAL NUM 813766

0.2 GAL/HR TEST
PER: MAR 21, 2023 PASS

***** END *****

MARATHON 3107
335 W. MCKINLEY
MISAWAKA IN 46545

MAR 21, 2023 10:13 AM

LIGJID STATUS

MAR 21, 2023 10:13 AM

L 2:DEAD SLOT
SENSOR NORMAL

L 3:DEAD SLOT
SENSOR NORMAL

L 4:INT PREM
SENSOR NORMAL

***** END *****

MARATHON 3107
335 W. MCKINLEY
MISAWAKA IN 46545

MAR 21, 2023 10:13 AM

LEAK TEST REPORT

T 1:REGULAR
PROBE SERIAL NUM 813581

TEST STARTING TIME:
OCT 19, 2017 11:48 AM

HEIGHT = 63.8 INCHES
WATER = 0.0 INCHES
TEMP = 65.1 F

TEST LENGTH = 2.3 HRS
STRT VOLUME = 8412.3 GAL
PERCENT VOLUME = 55.2

LEAK TEST RESULTS
RATE = -143.88 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST FAIL

***** END *****

MARATHON 3107
335 W. MCKINLEY
MISAWAKA IN 46545

MAR 21, 2023 10:13 AM

LEAK TEST REPORT

T 2:PREMIUM
PROBE SERIAL NUM 813766

TEST STARTING TIME:
OCT 19, 2017 11:48 AM

HEIGHT = 22.7 INCHES
WATER = 0.8 INCHES
TEMP = 79.8 F