

30 DAYS WALK THROUGH INSPECTION	
Facility Name	5476
Address	335 W MCINTIRE AVE, MARATHON, MI 49754
Operator on Duty Name	Robbin/Sean 46545
Operator Training current	Operator Training
Registration current with correct owner, operator etc.	Registration/Notification Form
Release Detection Method	Release Detection
Make and Model	ATG
Does it have paper?	Yes
Is it in Alarm mode?	Yes
Interstitial Monitoring Sensor Status Normal	Yes
Necessary Monthly Printout Taken	Yes
Are Spill Buckets Clean and free from water, debris, product etc?	Yes
Are the Spill Bucket in good condition and free of damage/cracks	Yes
Is Fill pipe cap tight and fill pipe free from any obstruction?	Yes
Are Sumps Clean and free from water, debris, product etc?	Yes
Are UDCs clean and free from water, debris, product etc?	Yes
NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.	
Operator on Duty Name	Signature
317-645-0215	Date
tanksdata@gmail.com	www.tanksdata.com
20220516	

MARATHON 3107
 335 W MCINTIRE
 49754-46545
 JUN 19, 2022 8:41 PM
 T 1: REGULAR
 PROBE SERIAL NUM 81381
 0.2 GAL/HR TEST
 PER: JUN 19, 2022 PASS
 T 2: PREMIUM
 PROBE SERIAL NUM 81381
 0.2 GAL/HR TEST
 PER: JUN 19, 2022 PASS
 ***** END *****
 JUN 19, 2022 8:41 PM
 LEAK TEST REPORT
 T 2: PREMIUM
 PROBE SERIAL NUM 81381