

MARATHON 3107
335 W.MCKINLEY
MISAWAKA IN 46545

FEB 21, 2023 12:50 PM

CSLD TEST RESULTS

FEB 21, 2023 12:50 PM

T 1:REGULAR
PROBE SERIAL NUM 812581

0.2 GAL/HR TEST
PER: FEB 21, 2023 PASS

T 2:PREMIUM
PROBE SERIAL NUM 812766

0.2 GAL/HR TEST
PER: FEB 21, 2023 PASS

***** END *****

MARATHON 3107
335 W.MCKINLEY
MISAWAKA IN 46545

FEB 21, 2023 12:50 PM

LIGID STATUS

FEB 21, 2023 12:50 PM

L 2:DEAD SLOT
SENSOR NORMAL

L 3:DEAD SLOT
SENSOR NORMAL

L 4:INT PREM
SENSOR NORMAL

***** END *****

MARATHON 3107
335 W.MCKINLEY
MISAWAKA IN 46545

FEB 21, 2023 12:50 PM

LEAK TEST REPORT

T 1:REGULAR
PROBE SERIAL NUM 812581

TEST STARTING TIME:
OCT 19, 2017 11:48 AM

HEIGHT = 53.8 INCHES
WATER = 0.0 INCHES
TEMP = 55.1 F

TEST LENGTH = 2.3 HRS
STRT VOLUME = 8412.3 GAL
PERCENT VOLUME = 55.2

LEAK TEST RESULTS
RATE = -143.89 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST FAIL

***** END *****

MARATHON 3107
335 W.MCKINLEY
MISAWAKA IN 46545

FEB 21, 2023 12:51 PM

LEAK TEST REPORT

T 2:PREMIUM
PROBE SERIAL NUM 812766

TEST STARTING TIME:
OCT 19, 2017 11:48 AM

HEIGHT = 22.7 INCHES
WATER = 0.8 INCHES
TEMP = 79.8 F