

MARATHON 3107
335 W.MCKINLEY
MISAWAKA IN 46545

JAN 19, 2023 12:00 PM

CSLD TEST RESULTS
- - - - -
JAN 19, 2023 12:00 PM

T 1:REGULAR
PROBE SERIAL NUM 813581
0.2 GAL/HR TEST
PER: JAN 19, 2023 PASS

T 2:PREMIUM
PROBE SERIAL NUM 813766
0.2 GAL/HR TEST
PER: JAN 19, 2023 PASS

* * * * * END * * * * *

MARATHON 3107
335 W.MCKINLEY
MISAWAKA IN 46545

JAN 19, 2023 12:00 PM

LIGJID STATUS
- - - - -
JAN 19, 2023 12:00 PM

L 2:DEAD SLOT
SENSOR NORMAL

L 3:DEAD SLOT
SENSOR NORMAL

L 4:INT PREM
SENSOR NORMAL

* * * * * END * * * * *

MARATHON 3107
335 W.MCKINLEY
MISAWAKA IN 46545

JAN 19, 2023 12:00 PM

LEAK TEST REPORT

T 1:REGULAR
PROBE SERIAL NUM 813581

TEST STARTING TIME:
OCT 19, 2017 11:48 AM

HEIGHT = 63.8 INCHES
WATER = 0.0 INCHES
TEMP = 65.1 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 8412.3 GAL
PERCENT VOLUME = 55.2

LEAK TEST RESULTS
RATE = -143.88 GAL/HR
TRSS = -0.13 GAL/HR
0.20 GAL/HR TEST FAIL

* * * * * END * * * * *

MARATHON 3107
335 W.MCKINLEY
MISAWAKA IN 46545

JAN 19, 2023 12:01 PM

LEAK TEST REPORT

T 2:PREMIUM
PROBE SERIAL NUM 813766

TEST STARTING TIME:
OCT 19, 2017 11:48 AM

HEIGHT = 22.7 INCHES
WATER = 0.8 INCHES
TEMP = 79.8 F

TEST LENGTH = 2.0 HRS