



UST TESTING/INSPECTION RESULTS SUMMARY

OWNER NAME: RL Petroleum
 ADDRESS: 335 W McKinley Ave
 CITY/STATE/ZIP: Mishawaka, IN 46545

TESTING DATE: 10/9/2023

LOCATION NAME: New Quick Stop
 LOCATION ADDRESS: 335 W McKinley Ave
 LOCATION CITY/STATE: Mishawaka, IN 46545
 LOCATION FID#: 05476

THREE YEAR TESTS/INSPECTIONS

SPILL BUCKET INTERGRITY TESTING

COMPLETED

TANK NO	PRODUCT	CONSTRUCTION	RESULT
1	RUL	Single-Walled	FAIL
1	RUL	Single-Walled	FAIL
2	PUL	Single-Walled	PASS

HYDROSTATIC SUMP TEST

NOT PERFORMED

SUMP ID	MATERIAL	DEPTH	HYDROSTATIC RESULT	VISUAL RESULT

OVERFILL EQUIPMENT INSPECTION

COMPLETED

TANK	PRODUCT	TYPE	BALL FLOAT RESULT	AUTO SHUT OFF RESULT
1	RUL	Automatic Shutoff Valve		UNTESTABLE
1	RUL	Automatic Shutoff Valve		UNTESTABLE
3	PUL	Automatic Shutoff Valve		PASS

OVERFILL ALARM TEST

NOT PERFORMED

TANK	PRODUCT	BRAND/MODEL	RESULT

LEGEND:

RUL	Regular Unleaded
DSL	Diesel
PUL	Premium Unleaded
KER	Kerosene
ODSL	Off Road Diesel
REC	Recreational

RECOMMENDATIONS:



UST TESTING/INSPECTION RESULTS SUMMARY

OWNER NAME: RL Petroleum
ADDRESS: 335 W McKinley Ave
CITY/STATE/ZIP: Mishawaka, IN 46545

LOCATION NAME: New Quick Stop
LOCATION ADDRESS: 335 W McKinley Ave
LOCATION CITY/STATE: Mishawaka, IN 46545
LOCATION FID#: 05476

TESTING DATE: **10/9/2023**

SITE PHOTOS

TEST DATE: 10/9/2023
LOCATION NAME: New Quick Stop
LOCATION ADDRESS: 335 W McKinley Ave
LOCATION CITY/STATE: Mishawaka, IN 46545
LOCATION PHONE: 317-645-0215
LOCATION CONTACT: Tanks Data/Virendar Kumar

OWNER NAME: RL Petroleum
OWNER ADDRESS: 335 W McKinley Ave
OWNER CITY/STATE/ZIP: Mishawaka, IN 46545
LOCATION FID#: 05476
WORK ORDER NO: NE-0548

SITE LOCATION



RUL1 SPILL BUCKET IMMEDIATE FAIL - FROM 10.5" TO 6" WITHIN 30 SECONDS



RUL2 SPILL BUCKET IMMEDIATE FAIL - FROM 12" TO 4" WITHIN 30 SECONDS



INTENTIONALLY LEFT BLANK

SITE PHOTOS

TEST DATE: 10/9/2023
LOCATION NAME: New Quick Stop
LOCATION ADDRESS: 335 W McKinley Ave
LOCATION CITY/STATE: Mishawaka, IN 46545
LOCATION PHONE: 317-645-0215
LOCATION CONTACT: Tanks Data/Virendar Kumar

OWNER NAME: RL Petroleum
OWNER ADDRESS: 335 W McKinley Ave
OWNER CITY/STATE/ZIP: Mishawaka, IN 46545
LOCATION FID#: 05476
WORK ORDER NO: NE-0548

PUL SPILL BUCKET TEST START 13.25"



PUL SPILL BUCKET TEST END 13.25"



PUL OVERFILL EQUIP TESTING



RUL1 - UNABLE TO REMOVE DROPTUBE





SITE PHOTOS

TEST DATE: 10/9/2023
LOCATION NAME: New Quick Stop
LOCATION ADDRESS: 335 W McKinley Ave
LOCATION CITY/STATE: Mishawaka, IN 46545
LOCATION PHONE: 317-645-0215
LOCATION CONTACT: Tanks Data/Virendar Kumar

OWNER NAME: RL Petroleum
OWNER ADDRESS: 335 W McKinley Ave
OWNER CITY/STATE/ZIP: Mishawaka, IN 46545
LOCATION FID#: 05476
WORK ORDER NO: NE-0548

RUL2 - UNABLE TO REMOVE DROPTUBE





CERTIFICATION VERIFICATION


RL Petroleum
335 W McKinley Ave
Mishawaka, IN 46545

Testing Date: 10/9/2023
New Quick Stop
Location of Test: 335 W McKinley Ave
Mishawaka, IN 46545
Site FID#: 05476
Service Technician: 0
Certified Technician: ADAM WILDER

Midwest ECS has completed the following tests/inspections at the above noted location:

ATG Functionality	
Leak Detector	
Elec Line Leak Detector	
Product Line Testing	
Liquid Sensor Functionality	
Spill Bucket	X
Containment Hydrostatic Sump	
Overfill Equipment Inspection	X
Overfill Alarm	
Vent Valve	
Interstitial	
Non-Volumetric Tank Tightness	
Shear Valve Inspection	

I, ADAM WILDER, the certified technician, was present throughout the duration of the testing and/or inspection performed by Midwest ECS at the above address on the above date. I affirm that the testing was done in accordance with Rule 229 IAC 9 and 40CFR Part 80, is accurate based upon the results received and that these forms accurately reflect the results of the testing and/or inspection.

Technician Signature: 

Technician Printed Name: ADAM WILDER

Date & Time: 10/09/2023 @ 1:00PM

	INDIANA HOMELAND SECURITY			
	Underground Storage Tank			
ADAM P WILDER 500 SIMS STREET FRANKFORT, INDIANA				
STATE/PERMIT # UC112310	ISSUE 01/30/2023	EFFECTIVE 01/30/2023	EXPIRATION 01/23/2025	
DISCIPLINES				
☒ Installation or Retrofitting				
☐ Cathodic Protection				
☐ Testing				
☐ Decommissioning Closure				
☐ Decommissioning Removal				

I attest with my signature below, that this technician was present onsite for testing as described above.