

MARATHON 3107
335 W.MCKINLEY
MISAWAKA IN 46545

JUN 2, 2024 1:43 PM

OSLO TEST RESULTS

JUN 2, 2024 1:43 PM

T 1:REGULAR
PROBE SERIAL NUM 810581

0.2 GAL/HR TEST
PER: JUN 2, 2024 PASS

T 2:PREMIUM
PROBE SERIAL NUM 810766

0.2 GAL/HR TEST
PER: JUN 2, 2024 PASS

* * * * * END * * * * *

MARATHON 3107
335 W.MCKINLEY
MISAWAKA IN 46545

JUN 2, 2024 1:43 PM

PRESSURE LINE LEAK
TEST RESULTS

Q 1:REGULAR

3.0 GAL/HR RESULTS:

LAST TEST:
JUN 2, 2024 1:37PM PASS

NUMBER OF TESTS PASSED
PREV 24 HOURS : 147
SINCE MIDNIGHT : 73

0.20 GAL/HR RESULTS:

DEC 25, 2015 12:00AM PASS
DEC 2, 2015 2:59AM PASS
DEC 29, 2015 7:13AM PASS
NOV 28, 2015 2:59AM PASS
NOV 26, 2015 8:58AM PASS
NOV 24, 2015 3:45AM PASS
NOV 22, 2015 5:17AM PASS
NOV 17, 2015 5:00AM PASS
NOV 15, 2015 7:24AM PASS
NOV 12, 2015 5:24AM PASS

0.10 GAL/HR RESULTS:

OCT 6, 2015 1:51AM PASS
APR 4, 2015 7:26AM PASS
SEP 30, 2014 4:45AM PASS
SEP 27, 2014 3:19AM PASS
MAR 27, 2012 4:07AM PASS
AUG 19, 2012 5:19AM PASS
FEB 15, 2012 5:47AM PASS
AUG 13, 2011 3:04AM PASS
FEB 6, 2011 1:31AM PASS
JUL 30, 2010 3:18AM PASS
JAN 27, 2010

Q 2:PREMIUM

3.0 GAL/HR RESULTS:

LAST TEST:
JUN 2.2024 1:42PM PASS

NUMBER OF TESTS PASSED
PREV 24 HOURS : 187
SINCE MIDNIGHT : 89

0.20 GAL/HR RESULTS:

DEC 3.2015 3:45AM PASS
NOV 30.2015 4:41AM PASS
NOV 29.2015 7:13AM PASS
NOV 28.2015 5:26AM PASS
NOV 27.2015 7:39AM PASS
NOV 23.2015 10:46PM PASS
NOV 22.2015 5:14AM PASS
NOV 19.2015 3:43AM PASS
NOV 16.2015 4:42AM PASS
NOV 12.2015 5:25AM PASS

0.10 GAL/HR RESULTS:

SEP 30.2015 12:57AM PASS
MAR 30.2015 5:27AM PASS
SEP 28.2014 8:54AM PASS
MAR 26.2014 3:47AM PASS
AUG 19.2012 4:08AM PASS
FEB 14.2012 2:50AM PASS
AUG 13.2011 5:48AM PASS
FEB 2.2011 3:53AM PASS
JUL 29.2010 3:36AM PASS
JAN 24.2010 3:44AM PASS

* * * * * END * * * * *

MARATHON 3107
335 W.MCKINLEY
MISAWAKA IN 46545

JUN 2, 2024 1:43 PM

LIQUID STATUS

JUN 2, 2024 1:43 PM

L 2:DEAD SLOT
SENSOR NORMAL

L 3:DEAD SLOT
SENSOR NORMAL

L 4:INT PREM
SENSOR NORMAL

* * * * * END * * * * *