

0000
Tanks Data

30 DAYS WALK THROUGH INSPECTION

UST Facility I.D. (FID) #	5476	Contact Number	
Facility Name	Marathon	Contact email	
Address	335 W McKinley	Date of Inspection	2-2-24
Operator on Duty Name		Name of the Person Conducting Inspection	Austin B
Operator Training			
Operator Training current	☒ Yes	☐ No	Operator Notified ☐ Yes ☐ No
Registration/Notification Form			
Is Registration current with correct owner, operator etc.	☐ Yes	☐ No	Operator Notified ☐ Yes ☐ No
Release Detection			
Release Detection Method	☒ ATG	☒ CIM	☐ SIR
Make and Model	VR	TR-350	☐ IC
Does it have paper?	☒ Yes	☐ No	Operator Notified ☐ Yes ☐ No
Is it in Alarm mode?	☒ Yes	☐ No	Operator Notified ☐ Yes ☐ No
Interstitial Monitoring Sensor Status Normal	☒ Yes	☐ No	Operator Notified ☐ Yes ☐ No
Necessary Monthly Printout Taken	☒ Yes	☐ No	Operator Notified ☐ Yes ☐ No
Spill Buckets			
Are Spill Buckets Clean and free from water, debris, product etc?	☒ Yes	☐ No	Operator Notified ☐ Yes ☐ No
Are the Spill Bucket in good condition and free of damage/cracks	☒ Yes	☐ No	Operator Notified ☐ Yes ☐ No
Fill Ports			
Is Fill pipe cap tight and fill pipe free from any obstruction?	☒ Yes	☐ No	Operator Notified ☐ Yes ☐ No
Piping/SFP Sumps			
Are Sumps Clean and free from water, debris, product etc?	☒ Yes	☐ No	Operator Notified ☐ Yes ☐ No
Under Dispenser Containments (UDC)			
Are UDCs clean and free from water, debris, product etc?	☒ Yes	☐ No	Operator Notified ☐ Yes ☐ No
NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.			
Operator on Duty Name		Signature	Date
317-645-0215		tanksdata@gmail.com	www.tanksdata.com