

MARATHON 3107
335 W.MCKINLEY
MISHAWAKA IN 46545

DEC 22, 2024 3:59 PM

CBLD TEST RESULTS

- - - - -

DEC 22, 2024 3:59 PM

T 1:REGULAR
PROBE SERIAL NUM 810581

0.2 GAL/HR TEST
PER: DEC 22, 2024 PASS

T 2:PREMIUM
PROBE SERIAL NUM 810766

0.2 GAL/HR TEST
PER: DEC 22, 2024 INCR

* * * * * END * * * * *

MARATHON 3107
335 W.MCKINLEY
MISHAWAKA IN 46545

DEC 22, 2024 3:59 PM

PRESSURE LINE LEAK
TEST RESULTS

Q 1:REGULAR

3.0 GAL/HR RESULTS:

LAST TEST:
DEC 22,2024 3:50PM PASS

NUMBER OF TESTS PASSED
PREV 24 HOURS : 149
SINCE MIDNIGHT : 80

0.20 GAL/HR RESULTS:

DEC	25,2015	12:00AM	PASS
DEC	2,2015	2:59AM	PASS
NOV	29,2015	7:13AM	PASS
NOV	28,2015	2:59AM	PASS
NOV	26,2015	8:58AM	PASS
NOV	24,2015	3:45AM	PASS
NOV	22,2015	5:17AM	PASS
NOV	17,2015	5:00AM	PASS
NOV	15,2015	7:24AM	PASS
NOV	12,2015	5:24AM	PASS

0.10 GAL/HR RESULTS:

OCT	6,2015	1:51AM	PASS
APR	4,2015	7:26AM	PASS
SEP	30,2014	4:45AM	PASS
MAR	27,2014	3:19AM	PASS
AUG	19,2012	4:07AM	PASS
FEB	15,2012	5:19AM	PASS
AUG	13,2011	5:47AM	PASS
FEB	6,2011	3:04AM	PASS
JUL	30,2010	1:31AM	PASS
JAN	27,2010	3:18AM	PASS

Q 2:PREMIUM

3.3 GAL/HR RESULTS:

LAST TEST:

DEC 22,2024 3:49PM PASS

NUMBER OF TESTS PASSED

PREV 24 HOURS : 170

SINCE MIDNIGHT : 87

0.23 GAL/HR RESULTS:

DEC 3,2015 3:45AM PASS

NOV 30,2015 4:41AM PASS

NOV 29,2015 7:13AM PASS

NOV 28,2015 5:26AM PASS

NOV 27,2015 7:39AM PASS

NOV 23,2015 10:46PM PASS

NOV 22,2015 5:14AM PASS

NOV 19,2015 3:43AM PASS

NOV 16,2015 4:42AM PASS

NOV 12,2015 5:25AM PASS

0.13 GAL/HR RESULTS:

SEP 30,2015 12:57AM PASS

MAR 30,2015 5:27AM PASS

SEP 28,2014 8:54AM PASS

MAR 26,2014 3:47AM PASS

AUG 19,2012 4:08AM PASS

FEB 14,2012 2:50AM PASS

AUG 13,2011 5:48AM PASS

FEB 2,2011 3:53AM PASS

JUL 29,2010 3:36AM PASS

JAN 24,2010 3:44AM PASS

* * * * * END * * * * *

MARATHON 3107
335 W.MCKINLEY
MISHAWAKA IN 46545

DEC 22, 2024 3:59 PM

LIQUID STATUS

DEC 22, 2024 3:59 PM

L 2:DEAD SLOT
SENSOR NORMAL

L 3:DEAD SLOT
SENSOR NORMAL

L 4:INT PREM
SENSOR NORMAL

* * * * * END * * * * *