

MARATHON 3107
335 W.MCKINLEY
MISHAWAKA IN 46545

NOV 8. 2024 2:06 PM

CSLD TEST RESULTS
NOV 8. 2024 2:06 PM

T 1:REGULAR
PROBE SERIAL NUM 810581
0.2 GAL/HR TEST
PER: NOV 8. 2024 PASS

T 2:PREMIUM
PROBE SERIAL NUM 810766
0.2 GAL/HR TEST
PER: NOV 8. 2024 PASS

* * * * * END * * * * *

MARATHON 3107
335 W.MCKINLEY
MISHAWAKA IN 46545

NOV 8. 2024 2:06 PM

LIQUID STATUS
NOV 8. 2024 2:06 PM

L 2:DEAD SLOT
SENSOR NORMAL

L 3:DEAD SLOT
SENSOR NORMAL

L 4:INT PREM
SENSOR NORMAL

* * * * * END * * * * *

MARATHON 3107
335 W.MCKINLEY
MISHAWAKA IN 46545

NOV 8. 2024 2:06 PM

PRESSURE LINE LEAK
TEST RESULTS

Q 1:REGULAR

3.0 GAL/HR RESULTS:

LAST TEST:
NOV 8.2024 2:03PM PASS

NUMBER OF TESTS PASSED
PREV 24 HOURS : 167
SINCE MIDNIGHT : 91

0.20 GAL/HR RESULTS:

DEC 25.2015 12:00AM PASS
 DEC 2.2015 2:59AM PASS
 NOV 29.2015 7:13AM PASS
 NOV 28.2015 2:59AM PASS
 NOV 26.2015 8:58AM PASS
 NOV 24.2015 3:45AM PASS
 NOV 22.2015 5:17AM PASS
 NOV 17.2015 5:00AM PASS
 NOV 15.2015 7:24AM PASS
 NOV 12.2015 5:24AM PASS

0.10 GAL/HR RESULTS:

OCT 6.2015 1:51AM PASS
 APR 4.2015 7:26AM PASS
 SEP 30.2014 4:45AM PASS
 MAR 27.2014 3:19AM PASS
 AUG 19.2012 4:07AM PASS
 FEB 15.2012 5:19AM PASS
 AUG 13.2011 5:47AM PASS
 FEB 6.2011 3:04AM PASS
 JUL 30.2010 1:31AM PASS
 JAN 27.2010 3:18AM PASS

Q 2:PREMIUM

3.0 GAL/HR RESULTS:

LAST TEST:
 NOV 8.2024 2:02PM PASS

NUMBER OF TESTS PASSED
 PREV 24 HOURS : 205
 SINCE MIDNIGHT : 112

0.20 GAL/HR RESULTS:

DEC 3.2015 3:45AM PASS
 NOV 30.2015 4:41AM PASS
 NOV 29.2015 7:13AM PASS
 NOV 28.2015 5:26AM PASS
 NOV 27.2015 7:39AM PASS
 NOV 23.2015 10:46PM PASS
 NOV 22.2015 5:14AM PASS
 NOV 19.2015 3:43AM PASS
 NOV 16.2015 4:42AM PASS
 NOV 12.2015 5:25AM PASS

0.10 GAL/HR RESULTS:

SEP 30.2015 12:57AM PASS
 MAR 30.2015 5:27AM PASS
 MAR 30.2014 8:54AM PASS
 SEP 28.2014 3:47AM PASS
 MAR 26.2014 4:08AM PASS
 AUG 19.2012 2:50AM PASS
 FEB 14.2012 5:48AM PASS
 AUG 13.2011 3:53AM PASS
 FEB 2.2011 3:36AM PASS
 JUL 29.2010 3:44AM PASS
 JAN 24.2010 3:44AM PASS

* * * * * END * * * * *