

MARATHON 3107
335 W.MCKINLEY
MISAWAKA IN 46545

AUG 13, 2025 3:05 PM
TEST RESULTS
AUG 13, 2025 3:05 PM

T 1:REGULAR
PROBE SERIAL NUM 810381
0.1 GAL/HR TEST
PER: AUG 13, 2025 PASS

T 2:PREMIUM
PROBE SERIAL NUM 810766
0.1 GAL/HR TEST
PER: AUG 13, 2025 PASS

***** END *****

MARATHON 3107
335 W.MCKINLEY
MISAWAKA IN 46545

AUG 13, 2025 3:05 PM
PRESSURE LINE LEAK
TEST RESULTS

9 2:PREMIUM

3.0 GAL/HR RESULTS:

LAST TEST:
AUG 13, 2025 3:02PM PASS

NUMBER OF TESTS PASSED
PREV 24 HOURS : 151
SINCE MIDNIGHT : 95

0.20 GAL/HR RESULTS:

DEC 3, 2015	3:45AM	PASS
NOV 30, 2015	4:41AM	PASS
NOV 29, 2015	7:13AM	PASS
NOV 28, 2015	5:26AM	PASS
NOV 27, 2015	7:39AM	PASS
NOV 23, 2015	10:46PM	PASS
NOV 22, 2015	5:14AM	PASS
NOV 19, 2015	3:43AM	PASS
NOV 16, 2015	4:42AM	PASS
NOV 12, 2015	5:25AM	PASS

0.10 GAL/HR RESULTS:

SEP 30, 2015	12:57AM	PASS
MAR 30, 2015	5:27AM	PASS
SEP 28, 2014	3:54AM	PASS
MAR 26, 2014	3:47AM	PASS
AUG 19, 2012	4:08AM	PASS
FEB 14, 2012	2:50AM	PASS
AUG 13, 2011	5:48AM	PASS
FEB 2, 2011	3:53AM	PASS
FEB 29, 2010	3:36AM	PASS
JAN 24, 2010	3:44AM	PASS

***** END *****

MARATHON 3107
335 W.MCKINLEY
MISAWAKA IN 46545

AUG 13, 2025 3:05 PM
LIQUID STATUS
AUG 13, 2025 3:05 PM

L 2:DEAD SLOT
SENSOR NORMAL

L 3:DEAD SLOT
SENSOR NORMAL

L 4:INT PREM
SENSOR NORMAL

***** END *****