

MARATHON 3107
335 W.MCKINLEY
MISHAWAKA IN 46545

MAR 19, 2025 3:11 PM

CSLD TEST RESULTS

MAR 19, 2025 3:11 PM

T 1:REGULAR
PROBE SERIAL NUM 810581

0.2 GAL/HR TEST
PER: MAR 19, 2025 PASS

T 2:PREMIUM
PROBE SERIAL NUM 810766

0.2 GAL/HR TEST
PER: MAR 19, 2025 PASS

* * * * * END * * * * *

MARATHON 3107
335 W.MCKINLEY
MISHAWAKA IN 46545

MAR 19, 2025 3:11 PM

PRESSURE LINE LEAK
TEST RESULTS

Q 2:PREMIUM

3.0 GAL/HR RESULTS:

LAST TEST:

MAR 19, 2025 3:07PM PASS

NUMBER OF TESTS PASSED

PREV 24 HOURS : 154

SINCE MIDNIGHT : 105

0.20 GAL/HR RESULTS:

DEC 3, 2015	3:45AM	PASS
NOV 30, 2015	4:41AM	PASS
NOV 29, 2015	7:13AM	PASS
NOV 28, 2015	5:26AM	PASS
NOV 27, 2015	7:39AM	PASS
NOV 23, 2015	10:46PM	PASS
NOV 22, 2015	5:14AM	PASS
NOV 19, 2015	3:43AM	PASS
NOV 16, 2015	4:42AM	PASS
NOV 12, 2015	5:25AM	PASS

0.10 GAL/HR RESULTS:

SEP 30, 2015	12:57AM	PASS
MAR 30, 2015	5:27AM	PASS
SEP 28, 2014	8:54AM	PASS
MAR 26, 2014	3:47AM	PASS
AUG 19, 2012	4:08AM	PASS
FEB 14, 2012	2:50AM	PASS
AUG 13, 2011	5:48AM	PASS
FEB 2, 2011	3:53AM	PASS
JUL 29, 2010	3:36AM	PASS
JAN 24, 2010	3:44AM	PASS

* * * * * END * * * * *

MARATHON 3107
335 W.MCKINLEY
MISHAWAKA IN 46545

MAR 19, 2025 3:11 PM

LIQUID STATUS

MAR 19, 2025 3:11 PM

L 2:DEAD SLOT
SENSOR NORMAL

L 3:DEAD SLOT
SENSOR NORMAL

L 4:INT PREM
SENSOR NORMAL

* * * * * END * * * * *