

MARATHON 3107
335 W.MCKINLEY
MISHAWAKA IN 46545

FEB 27. 2025 4:10 PM

CSLD TEST RESULTS

FEB 27. 2025 4:10 PM

T 1:REGULAR
PROBE SERIAL NUM 810581

0.2 GAL/HR TEST
PER: FEB 27. 2025 PASS

T 2:PREMIUM
PROBE SERIAL NUM 810766

0.2 GAL/HR TEST
PER: FEB 27. 2025 PASS

* * * * * END * * * * *

MARATHON 3107
335 W.MCKINLEY
MISHAWAKA IN 46545

FEB 27. 2025 4:10 PM

PRESSURE LINE LEAK
TEST RESULTS

2 2:PREMIUM

3.3 GAL/HR RESULTS:

LAST TEST:
FEB 27.2025 4:07PM PASS

NUMBER OF TESTS PASSED
PREV 24 HOURS : 166
SINCE MIDNIGHT : 113

0.20 GAL/HR RESULTS:

DEC 3.2015	3:45AM	PASS
NOV 30.2015	4:41AM	PASS
NOV 29.2015	7:13AM	PASS
NOV 28.2015	5:26AM	PASS
NOV 27.2015	7:39AM	PASS
NOV 23.2015	10:46PM	PASS
NOV 22.2015	5:14AM	PASS
NOV 19.2015	3:43AM	PASS
NOV 16.2015	4:42AM	PASS
NOV 12.2015	5:25AM	PASS

0.10 GAL/HR RESULTS:

SEP 30.2015	12:57AM	PASS
MAR 30.2015	5:27AM	PASS
SEP 28.2014	8:54AM	PASS
MAR 26.2014	3:47AM	PASS
AUG 19.2012	4:08AM	PASS
FEB 14.2012	2:50AM	PASS
AUG 13.2011	5:48AM	PASS
FEB 2.2011	3:53AM	PASS
JUL 29.2010	3:36AM	PASS
JAN 24.2010	3:44AM	PASS

* * * * * END * * * * *

MARATHON 3107
335 W.MCKINLEY
MISHAWAKA IN 46545

FEB 27. 2025 4:10 PM

LIQUID STATUS

FEB 27. 2025 4:10 PM

L 2:DEAD SLOT

SENSOR NORMAL

L 3:DEAD SLOT

SENSOR NORMAL

L 4:INT PREM

SENSOR NORMAL

* * * * * END * * * * *