

MARATHON 3107  
335 W.MCKINLEY  
MISHAWAKA IN 46545

JUL 10, 2025 1:48 PM

OSLO TEST RESULTS

JUL 10, 2025 1:48 PM

T 1:REGULAR  
PROBE SERIAL NUM 810581

0.2 GAL/HR TEST  
PER: JUL 10, 2025 PASS

T 2:PREMIUM  
PROBE SERIAL NUM 810766

0.2 GAL/HR TEST  
PER: JUL 10, 2025 PASS

\*\*\*\*\* END \*\*\*\*\*

MARATHON 3107  
335 W.MCKINLEY  
MISHAWAKA IN 46545

JUL 10, 2025 1:48 PM

LIQJID STATUS

JUL 10, 2025 1:48 PM

L 2:DEAD SLOT  
SENSOR NORMAL

L 3:DEAD SLOT  
SENSOR NORMAL

L 4:INT PREM  
SENSOR NORMAL

\*\*\*\*\* END \*\*\*\*\*

MARATHON 3107  
335 W.MCKINLEY  
MISHAWAKA IN 46545

JUL 10, 2025 1:48 PM

PRESSURE LINE LEAK  
TEST RESULTS

Q 2:PREMIUM

3.0 GAL/HR RESULTS:

LAST TEST:  
JUL 10, 2025 1:42PM PASS

NUMBER OF TESTS PASSED  
PREV 24 HOURS : 186

SINCE MIDNIGHT : 97

0.20 GAL/HR RESULTS:

|              |         |      |
|--------------|---------|------|
| DEC 3, 2015  | 3:45AM  | PASS |
| NOV 30, 2015 | 4:41AM  | PASS |
| NOV 29, 2015 | 7:13AM  | PASS |
| NOV 28, 2015 | 5:26AM  | PASS |
| NOV 27, 2015 | 7:39AM  | PASS |
| NOV 23, 2015 | 10:46PM | PASS |
| NOV 22, 2015 | 5:14AM  | PASS |
| NOV 19, 2015 | 3:43AM  | PASS |
| NOV 16, 2015 | 4:42AM  | PASS |
| NOV 12, 2015 | 5:25AM  | PASS |

0.10 GAL/HR RESULTS:

|              |         |      |
|--------------|---------|------|
| SEP 30, 2015 | 12:57AM | PASS |
| MAR 30, 2015 | 5:27AM  | PASS |
| SEP 28, 2014 | 8:54AM  | PASS |
| MAR 26, 2014 | 3:47AM  | PASS |
| AUG 19, 2012 | 4:08AM  | PASS |
| FEB 14, 2012 | 2:50AM  | PASS |
| AUG 13, 2011 | 5:48AM  | PASS |
| FEB 2, 2011  | 3:53AM  | PASS |
| JUL 29, 2010 | 3:36AM  | PASS |
| JAN 24, 2010 | 3:44AM  | PASS |

\*\*\*\*\* END \*\*\*\*\*