

5512
4013 S US 31
KOKOMO IN 46902
765-450-8426

OCT 23, 2025 5:21 PM

CELD TEST RESULTS

OCT 23, 2025 5:21 PM

T 1:RUL
PROBE SERIAL NUM 233932

0.2 GAL/HR TEST
PER: OCT 23, 2025 PASS

T 2:PUL
PROBE SERIAL NUM 233933

0.2 GAL/HR TEST
PER: OCT 23, 2025 PASS

T 3:DIESEL
PROBE SERIAL NUM 233934

0.2 GAL/HR TEST
PER: OCT 23, 2025 PASS

***** END *****

5512
4013 S US 31
KOKOMO IN 46902
765-450-8426

OCT 23, 2025 5:21 PM

LIQUID STATUS

OCT 23, 2025 5:21 PM

L 1:RNL
SENSOR NORMAL

L 2:PUL
SENSOR NORMAL

L 3:RUL
SENSOR NORMAL

L 4:NL INT
SENSOR NORMAL

L 5:PREM DIESEL INT
SENSOR NORMAL

***** END *****

5512
4013 S US 31
KOKOMO IN 46902
765-450-8426

OCT 23, 2025 5:21 PM

LIQUID STATUS

OCT 23, 2025 5:21 PM

L 1:RNL
SENSOR NORMAL

L 2:PUL
SENSOR NORMAL

L 3:RUL
SENSOR NORMAL

L 4:NL INT
SENSOR NORMAL

L 5:PREM DIESEL INT
SENSOR NORMAL

***** END *****