

PETROLEUM TESTING SERVICES, LLC
PO BOX 146
YORKTOWN, IN 47396
765-749-5540
EMAIL:petroleumtesting@aol.com

SITE: FID 15670
ADDRESS: 26499 US 20
CITY,ST,ZIP: SOUTH BEND, IN 46628

DATE: 6/6/2023

ATG FUNCTIONALITY

ATG MAKE AND MODEL

VR 450

TANK NUMBER

PRODUCT

TANK VOLUME

TANK DIAMETER

TANK PROBE HAS NO DAMAGED PARTS?

DAMAGED OR MISSING PARTS REPLACED?

FLOATS MOVE FREELY ON STEM?

FUEL FLOAT AGREES W/ CONSOLE?

INCH LEVEL WATER FLOAT ACTIVATES ALARM?

WATER FLOAT AGREES W/ CONSOLE?

INCH LEVEL OVERFILL ACTIVATES ALARM?

OVERFILL ALARM AGREES W/ CONSOLE?

ALL SENSORS LABELED CORRECTLY?

STP/UDC SENSORS ACTIVATE ALARM?

INTERSTITIAL TANK SENSORS ACTIVATE ALARM?

.2 MONTHLY MONITORING ACTIVE?

BATTERY BACKUP IS FUNCTIONAL?

RESULT

COMMENTS:

1	2	3	4	5
UNL	DIESEL	PREMIUM	DSL 4K	
12032	8022	6016	4032	
96	96	96	96	
N	N	N	N	
NA	NA	NA	NA	
Y	Y	Y	Y	
Y	Y	Y	Y	
1	1	1	1	
Y	Y	Y	Y	
82	82	82	82	
Y	Y	Y	Y	
NA	NA	NA	NA	
NA	NA	NA	NA	
NA	NA	NA	NA	
Y	Y	Y	Y	
YES				
PASS	PASS	PASS	PASS	

TECHNICIAN: JOHN LANNOM

CERTIFICATION:

UC20129333