

PETROLEUM TESTING SERVICES, LLC
PO BOX 146
YORKTOWN, IN 47396
765-749-5540
EMAIL:petroleumtesting@aol.com

SITE NAME: FID 15670
STREET NAME: 26499 US 20
CITY,STATE,ZIP: SOUTH BEND, IN 46628
DATE: 6/6/2023 TIME: 9:00A

LINE AND LEAK DETECTOR TEST

PRODUCT	UNL	PREM	DSL	4	5
OPERATING SYSTEM	PR	PR	PR		
STP MODEL	RJ	RJ	RJ		
OPERATING PRESSURE	30	30	30		
TEST PRESSURE	50	50	50		
ISOLATION	CV	CV	CV		
LINE MATERIAL	FG	FG	FG		
BEGINNING LEVEL	0.0450	0.0825	0.0780		
10 MIN	0.0450	0.0825	0.0780		
20 MIN	0.0450	0.0825	0.0780		
30 MIN	0.0450	0.0825	0.0780		
AMOUNT OF CHANGE	0.0000	0.0000	0.0000		
RESULT	PASS	PASS	PASS		
LEAK DETECTOR MODEL	VMI	RJ	RJ		
LEAK DETECTOR MAKE	LD2000	XLD	FX1DV		
OPENING TIME	2	2	2		
PAUSE PRESSURE	20	10	10		
HOLDING PRESSURE	14	12	15		
TYPE OF TEST	3GAL/HR	3GAL/HR	3GAL/HR		
RESULT	PASS	PASS	PASS		

COMMENTS

TECHNICIAN JOHN LANNOM CERTIFICATION UC20129333