

PETROLEUM TESTING SERVICES, LLC

PO BOX 146

YORKTOWN, IN 47396

765-749-5540 EMAIL: petroleumtesting@aol.com

SITE: FID 15670 FID 4738

ADDRESS: 26499 US 20

CITY/ST/ZIP: SOUTH BEND, IN 46628

DATE: 6/6/2023 TIME: 9:00A

OVERFILL TEST

	1	2	3	4	5
PRODUCT	UNL	PREM	DSL	DYED DSL	
TYPE OF OVERFILL	AUTO	AUTO	AUTO	AUTO	
TANK SIZE	12032	8022	6016	4032	
TANK DIAMETER	96	96	96	96	
RISER LENGTH	23	27	32	24	
TOP OF RISER TO OVERFILL	36	38	45	39	
OVERFILL FROM TANK BOTTOM	83	85	83	81	
OVERFILL IS SET @ 95% OR LESS?	Y	Y	Y	Y	
RESULT	PASS	PASS	PASS	PASS	

COMMENTS:

TECHNICIAN: JOHN LANNOM

CERTIFICATION

UC20129333