

Tanks Data

30 DAYS WALK THROUGH INSPECTION

UST Facility I.D. (FID) #	15670	Contact Number	
Facility Name		Contact email	
Address	2649905 Hwy 80 W South Bend	Date of Inspection	04-26-25
Operator on Duty Name	Joe 46628	Name of the Person Conducting Inspection	Robert Singh

Operator Training current	☒ Yes	☐ No	Operator Notified	☒ Yes	☐ No
Registration current with correct owner, operator etc.	☒ Yes	☐ No	Operator Notified	☒ Yes	☐ No
Release Detection Method	☒ DATG ☒ VR-TL & 450 lbs	☐ CIM ☐ SIR	Operator Notified	☒ Yes	☐ No
Make and Model			Operator Notified	☒ Yes	☐ No
Does it have paper?	☒ Yes	☐ No	Operator Notified	☒ Yes	☐ No
Is it in Alarm mode?	☒ Yes	☐ No	Operator Notified	☒ Yes	☐ No
Interstitial Monitoring Sensor Status Normal	☒ Yes	☐ No	Operator Notified	☒ Yes	☐ No
Necessary Monthly Printout Taken	☒ Yes	☐ No	Operator Notified	☒ Yes	☐ No
Spill Buckets	☒ Yes	☐ No	Operator Notified	☒ Yes	☐ No
Are Spill Buckets Clean and free from water, debris, product etc?	☒ Yes	☐ No	Operator Notified	☒ Yes	☐ No
Are the Spill Bucket in good condition and free of damage/cracks	☒ Yes	☐ No	Operator Notified	☒ Yes	☐ No
Is Fill pipe cap tight and fill pipe free from any obstruction?	☒ Yes	☐ No	Operator Notified	☒ Yes	☐ No
Piping/STP Sumps	☒ Yes	☐ No	Operator Notified	☒ Yes	☐ No
Are Sumps Clean and free from water, debris, product etc?	☒ Yes	☐ No	Operator Notified	☒ Yes	☐ No
Under Dispenser Containments (UDC)	☒ Yes	☐ No	Operator Notified	☒ Yes	☐ No
Are UDCs clean and free from water, debris, product etc?	☒ Yes	☐ No	Operator Notified	☒ Yes	☐ No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OF ACCORDING TO EXISTING RULES AND REGULATIONS FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name: _____ Signature: _____ Date: _____

tanksdata@gmail.com www.tanksdata.com 20220516