

914 E WATERFORD
WAKARUSA, IN 46573
219-362-4637

MAY 12, 2023 10:52

LIQUID STATUS

MAY 12, 2023 10:52

NONE

* * * * * END * * * * *

914 E WATERFORD
WAKARUSA, IN 46573
219-362-4637

MAY 12, 2023 10:52

LEAK TEST REPORT

C 1:RNL
PROBE SERIAL NUM 571114

TEST STARTING TIME:
MAY 11, 2023 23:30

HEIGHT = 57.2 INCHES
WATER = 0.0 INCHES
TEMP = 57.0 F

TEST LENGTH = 3.0 HRS
STRT VOLUME = 6313.7 GAL
PERCENT VOLUME = 62.2

LEAK TEST RESULTS
RATE = -0.23 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST FAIL

* * * * * END * * * * *

914 E WATERFORD
WAKARUSA, IN 46573
219-362-4637

MAY 12, 2023 10:52

LEAK TEST REPORT

C 2:113 RUL
PROBE SERIAL NUM 571116

TEST STARTING TIME:
MAY 11, 2023 23:30

HEIGHT = 58.8 INCHES
WATER = 0.0 INCHES
TEMP = 57.6 F