

PETROLEUM TESTING SERVICES, LLC
PO BOX 146
YORKTOWN, IN 47396
765-749-5540
EMAIL:petroleumtesting@aol.com

SITE: MARATHON
ADDRESS: 914 WATERFORD ST
CITY,ST,ZIP: WAKARUSA, IN 46573

FID 8958

DATE: 2/7/2023

ATG FUNCTIONALITY

ATG MAKE AND MODEL

TANK NUMBER

PRODUCT

TANK VOLUME

TANK DIAMETER

TANK PROBE HAS NO DAMAGED PARTS?

DAMAGED OR MISSING PARTS REPLACED?

FLOATS MOVE FREELY ON STEM?

FUEL FLOAT AGREES W/ CONSOLE?

INCH LEVEL WATER FLOAT ACTIVATES ALARM?

WATER FLOAT AGREES W/ CONSOLE?

INCH LEVEL OVERFILL ACTIVATES ALARM?

OVERFILL ALARM AGREES W/ CONSOLE?

ALL SENSORS LABELED CORRECTLY?

STP/UDC SENSORS ACTIVATE ALARM?

INTERSTITIAL TANK SENSORS ACTIVATE ALARM?

.2 MONTHLY MONITORING ACTIVE?

BATTERY BACKUP IS FUNCTIONAL?

RESULT

COMMENTS:

VR 350

1	2	3	4	5
UNL	UNL	PREM	DSL	
10144	8272	3782	6084	
96	96	71	91	
N	N	N	N	
NA	NA	NA	NA	
Y	Y	Y	Y	
Y	Y	Y	Y	
2	2	2	2	
Y	Y	Y	Y	
81	81	59	82	
Y	Y	Y	Y	
NA	NA	NA	NA	
NA	NA	NA	NA	
NA	NA	NA	NA	
Y	Y	Y	Y	
YES				
PASS	PASS	PASS	PASS	

TECHNICIAN: RONNIE BROWN

CERTIFICATION:

UC2017IN12086