001

30 DAYS WALK THROUGH INSPECTION

UST Facility I.D.((FID) # 8458	Contact Number
Facility Name MARATHON	Contact email
Address 914 E Waterford St Wakarusa IN 46573	Date of Inspection 6/7/2022
Operator on Duty Name Sam.	Name of the Person Conducting Inspection Vilendez

Operator Training				
Operator Training current	◯ Yes	◯ No	OperatorNotified	◯ Yes ◯ No
Registration/Notification Form				
Is Registration current with correct owner, operator etc.	◯ Yes	◯ No	OperatorNotified	◯ Yes ◯ No
Release Detection				
Release Detection Method	☒ ATG	◯ TIM	◯ IR	◯ IC ◯ Other
Make and Model	TLS 350			
Does it have paper?	☒ Yes	◯ No	OperatorNotified	◯ Yes ◯ No
Is it in Alarm mode?	☒ Yes	◯ No	OperatorNotified	◯ Yes ◯ No
Interstitial Monitoring Sensor Status Normal	◯ Yes	☒ No	OperatorNotified	◯ Yes ◯ No
Necessary Monthly Printout Taken	☒ Yes	◯ No	OperatorNotified	◯ Yes ◯ No
Spill Buckets				
Are Spill Buckets Clean and free from water, debris, product etc?	◯ Yes	☒ No	OperatorNotified	☒ Yes ◯ No
Are the Spill Bucket in good condition and free of damage/cracks	☒ Yes	◯ No	OperatorNotified	◯ Yes ◯ No
Fill Ports				
Is Fill pipe cap tight and fill pipe free from any obstruction?	☒ Yes	◯ No	OperatorNotified	◯ Yes ◯ No
Piping/STP Sumps				
Are Sumps Clean and free from water, debris, product etc?	◯ Yes	☒ No	OperatorNotified	☒ Yes ◯ No
Under Dispenser Containments (UDC)				
Are UDCs clean and free from water, debris, product etc?	◯ Yes	☒ No	OperatorNotified	☒ Yes ◯ No

NOTE: ALL LIQUID/DERRIS OR WASTE MUST BE DISPOSSED OFF ACCORDING TO EXISTING RULES AND REQULATIONS FOLLOWING PROPER PROCEDUE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name	Signature	Date
317-645-0215		www.tankdata.com

* * * * * END * * * * *

914 E WATERFORD
WAKARUSA,IN 46573
219-862-4637

JUN 7, 2022 13:49

LEAK TEST REPORT

- :RNL
PROBE SERIAL NUM 571114

TEST STARTING TIME:
JUN 6, 2022 23:30

HEIGHT = 41.0 INCHES
WATER = 0.0 INCHES
TEMP = 64.4 F

TEST LENGTH = 3.0 HRS
STRT VOLUME = 4124.1 GAL
PERCENT VOLUME = 40.7

LEAK TEST RESULTS
0.20 GAL/HR TEST INVL

0.20 GAL/HR FLAGS:
PRODUCT LEVEL INCREASE

* * * * * END * * * * *

914 E WATERFORD
WAKARUSA,IN 46573
219-862-4637

JUN 7, 2022 13:49

LEAK TEST REPORT