

914 E WATERFORD
WAKARUSA, IN 46573
219-362-4637

JUL 18, 2023 11:22

LIQUID STATUS

JUL 18, 2023 11:22

NONE

* * * * * END * * * * *

914 E WATERFORD
WAKARUSA, IN 46573
219-362-4637

JUL 18, 2023 11:22

LEAK TEST REPORT

C 1:RNL
PROBE SERIAL NUM 571114

TEST STARTING TIME:
JUL 17, 2023 23:30

HEIGHT = 58.0 INCHES
WATER = 0.0 INCHES
TEMP = 68.5 F

TEST LENGTH = 3.0 HRS
STRT VOLUME = 6370.8 GAL
PERCENT VOLUME = 62.8

LEAK TEST RESULTS
0.20 GAL/HR TEST INVL

0.20 GAL/HR FLAGS:
PRODUCT LEVEL INCREASE

* * * * * END * * * * *

914 E WATERFORD
WAKARUSA, IN 46573
219-362-4637

JUL 18, 2023 11:22

LEAK TEST REPORT

C 2:113 RUL
PROBE SERIAL NUM 571116

TEST STARTING TIME:
JUL 17, 2023 23:30

HEIGHT = 59.5 INCHES
WATER = 0.0 INCHES
TEMP = 70.0 F