



EZY CHECK SYSTEMS PRODUCT LINE TESTER DATA SHEET

TEST DATE: 8/30/2023
LOCATION NAME: Wakarusa C Store
LOCATION ADDRESS: 914 E Waterford Street
LOCATION CITY/STATE: Wakarusa, IN 46573
LOCATION PHONE: 0
LOCATION CONTACT: Virendar Kumar

WORK ORDER NO: NE-0549
LOCATION FID#: 08958

APPLIED PRESSURE: 50PSI

#1	PRODUCT TYPE:			RUL		
TIME	DATA	-/+	GPL	RES	GPH	
8:35	60	0	0.0037	0.0000	0.0000	
8:50	57	3	0.0037	0.0111	0.0444	
9:05	55	2	0.0037	0.0074	0.0296	
			0.0037			
			0.0037			
			0.0037			
FINAL RESULT		PASS		0.0444		

#2	PRODUCT TYPE:		PUL		
TIME	DATA	-/+	GPL	RES	GPH
8:35	80	0	0.0037	0.0000	0.0000
8:50	79	1	0.0037	0.0037	0.0148
9:05	79	1	0.0037	0.0037	0.0148
			0.0037		
			0.0037		
			0.0037		
FINAL RESULT		PASS		0.0148	

#3	PRODUCT TYPE:			DSL		
TIME	DATA	-/+	GPL	RES	GPH	
8:35	64	0	0.0037	0.0000	0.0000	
8:50	63	1	0.0037	0.0037	0.0148	
9:05	63	0	0.0037	0	0	
			0.0037			
			0.0037			
			0.0037			
FINAL RESULT		PASS		0.0148		

#4	PRODUCT TYPE:				
TIME	DATA	-/+	GPL	RES	GPH
		0	0.0037	0.0000	0.0000
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
FINAL RESULT			-		

#5	PRODUCT TYPE:				
TIME	DATA	-/+	GPL	RES	GPH
		0	0.0037	0.0000	0.0000
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
FINAL RESULT		-			

#6	PRODUCT TYPE:				
TIME	DATA	-/+	GPL	RES	GPH
		0	0.0037	0.0000	0.0000
			0.0037		
			0.0037		
			0.0037		
			0.0037		
			0.0037		
FINAL RESULT			-		

0

SERVICE TECHNICIAN NAME (printed)

ADAM WILDER

CERTIFIED TECHNICIAN NAME (printed)

SERVICE TECHNICIAN SIGNATURE

CERTIFIED TECHNICIAN SIGNATURE

CERT NO: UC112310
EXPIRATION DATE: 1/23/2025