

914 Z WATERFORD
UPPARUSA, IN 46573
219-362-4637

FEB 12, 2024 13:51

LIQUID STATUS

FEB 12, 2024 13:51

NONE

*****END*****

914 Z WATERFORD
UPPARUSA, IN 46573
219-362-4637

FEB 12, 2024 13:51

LEAK TEST REPORT

-- 136L
PROBE SERIAL NUM 571114

TEST STARTING TIME:

FEB 12, 2024 23:20

HEIGHT = 62.7 INCHES
WATER = 0.0 INCHES
TEMP = 43.8 F

TEST LENGTH = 3.0 HRS
STRT VOLUME = 6772.1 GAL
PERCENT VOLUME = 56.9

LEAK TEST RESULTS
RATE = -2.23 GAL/HR
THRS = -0.13 GAL/HR
C 23 GAL/HR TEST FAIL
*****END*****

914 Z WATERFORD
UPPARUSA, IN 46573
219-362-4637

FEB 12, 2024 13:52

LEAK TEST REPORT

-- 211.3 RUL
PROBE SERIAL NUM 571116

TEST STARTING TIME:

FEB 12, 2024 23:30

HEIGHT = 54.6 INCHES
WATER = 0.0 INCHES
TEMP = 43.8 F

TEST LENGTH = 3.0 HRS
STRT VOLUME = 4910.0 GAL
PERCENT VOLUME = 59.4

LEAK TEST RESULTS
RATE = -0.58 GAL/HR
THRS = -0.13 GAL/HR
C 23 GAL/HR TEST FAIL
*****END*****

914 Z WATERFORD
UPPARUSA, IN 46573
219-362-4637

FEB 12, 2024 13:52

LEAK TEST REPORT

-- 3114 PUL
PROBE SERIAL NUM 520013

TEST STARTING TIME:

FEB 11, 2024 23:30

HEIGHT = 35.7 INCHES
WATER = 0.0 INCHES
TEMP = 47.0 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 1992.8 GAL
PERCENT VOLUME = 52.7

LEAK TEST RESULTS
RATE = -0.00 GAL/HR
THRS = -0.13 GAL/HR
C 23 GAL/HR TEST PASS
*****END*****

914 Z WATERFORD
UPPARUSA, IN 46573
219-362-4637

FEB 12, 2024 13:52

LEAK TEST REPORT

-- 4126 DEL
PROBE SERIAL NUM 571115

TEST STARTING TIME:

FEB 11, 2024 23:30

HEIGHT = 52.3 INCHES
WATER = 0.0 INCHES
TEMP = 47.1 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 3658.9 GAL
PERCENT VOLUME = 60.1

LEAK TEST RESULTS
RATE = -0.00 GAL/HR
THRS = -0.13 GAL/HR
C 23 GAL/HR TEST PASS