

914 E WATERFORD
WPAKARUSA, IN 46573
219-362-4637

MAR 11, 2024 15:26

LEAK TEST REPORT

C 1:RNL
PROBE SERIAL NUM 571114

TEST STARTING TIME:
MAR 10, 2024 23:30

HEIGHT = 49.5 INCHES
WATER = 0.0 INCHES
TEMP = 47.7 F

TEST LENGTH = 3.0 HRS
STRT VOLUME = 5317.3 GAL
PERCENT VOLUME = 52.4

LEAK TEST RESULTS
RATE = -0.74 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST FAIL

***** END *****

914 E WATERFORD
WPAKARUSA, IN 46573
219-362-4637

MAR 11, 2024 15:26

LEAK TEST REPORT

C 2:113 RUL
PROBE SERIAL NUM 571116

TEST STARTING TIME:
MAR 10, 2024 23:30

HEIGHT = 51.3 INCHES
WATER = 0.0 INCHES
TEMP = 48.1 F

TEST LENGTH = 3.0 HRS
STRT VOLUME = 4539.5 GAL
PERCENT VOLUME = 54.9

LEAK TEST RESULTS
RATE = -0.92 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST FAIL

***** END *****

914 E WATERFORD
WPAKARUSA, IN 46573
219-362-4637

MAR 11, 2024 15:26

LEAK TEST REPORT