

914 3 WATERFORD
UPPARUSA,IN 46573
219-362-4637
JAN 2, 2024 13:15
LIQUID STATUS

JAN 2, 2024 13:15
NONE
*****END*****

914 3 WATERFORD
UPPARUSA,IN 46573
219-362-4637
JAN 2, 2024 13:15
LEAK TEST REPORT
T 2:11L RUL
PROBE SERIAL NUM 571114
TEST STARTING TIME:
JAN 1, 2024 23:30
HE G47 = 74.4 INCHES
UPTEX = 0.0 INCHES
TEMP = 47.1 F
TEST LENGTH = 3.0 HRS
STRT VOLUME = 8509.7 GAL
PERCENT VOLUME = 83.9
LEAK TEST RESULTS
0.23 GAL/HR TEST INVL
0.20 GAL/HR FLAG:
FRODOJT LEVEL INCREASE
*****END*****

914 3 WATERFORD
UPPARUSA,IN 46573
219-362-4637
JAN 2, 2024 13:15
LEAK TEST REPORT
T 2:11.3 RUL
PROBE SERIAL NUM 571116
TEST STARTING TIME:
JAN 1, 2024 23:30
HE G47 = 76.3 INCHES
UPTEX = 0.0 INCHES
TEMP = 47.4 F
TEST LENGTH = 3.0 HRS
STRT VOLUME = 7111.0 GAL
PERCENT VOLUME = 86.0
LEAK TEST RESULTS
RAT2 = -0.07 GAL/HR
THRS = -0.13 GAL/HR
0.23 GAL/HR TEST FAIL
*****END*****

914 3 WATERFORD
UPPARUSA,IN 46573
219-362-4637
JAN 2, 2024 13:15
LEAK TEST REPORT
T 3:11.4 PUL
PROBE SERIAL NUM 520013
TEST STARTING TIME:
JAN 1, 2024 23:30
HE G47 = 37.2 INCHES
UPTEX = 0.0 INCHES
TEMP = 52.7 F
TEST LENGTH = 2.0 HRS
STRT VOLUME = 2089.8 GAL
PERCENT VOLUME = 55.3
LEAK TEST RESULTS
RAT2 = -0.00 GAL/HR
THRS = -0.13 GAL/HR
0.23 GAL/HR TEST PASS
*****END*****

914 3 WATERFORD
UPPARUSA,IN 46573
219-362-4637
JAN 2, 2024 13:15
LEAK TEST REPORT
T 4:12.6 DEL
PROBE SERIAL NUM 571115
TEST STARTING TIME:
JAN 1, 2024 23:30
HE G47 = 37.5 INCHES
UPTEX = 0.0 INCHES
TEMP = 51.5 F
TEST LENGTH = 2.0 HRS
STRT VOLUME = 2302.4 GAL
PERCENT VOLUME = 38.3
LEAK TEST RESULTS
RAT2 = 0.01 GAL/HR
THRS = -0.13 GAL/HR