



UST TESTING/INSPECTION RESULTS SUMMARY

OWNER NAME: Tanks Data
OWNER ADDRESS: 914 E Waterford Street
OWNER CITY/STATE/ZIP: Wakarusa, IN 46573

TESTING DATE: 8/30/2023

LOCATION NAME: Wakarusa C Store
LOCATION ADDRESS: 914 E Waterford Street
LOCATION CITY/STATE: Wakarusa, IN 46573
LOCATION FID#: 08958

METHOD OF TANK LEAK DETECTION: -
METHOD OF PIPING LEAK DETECTION: -
TYPE OF UNDERGROUND PIPING: -

ANNUAL TESTING/INSPECTIONS

AUTOMATIC TANK GAUGE TEST

NOT PERFORMED

TANK NO	PRODUCT	BRAND/MODEL	RESULT

PRODUCT LINE TEST

COMPLETED

Product line must be within manufacturer's criteria of +/- .050 GPH.

LINE NO	PRODUCT	RESULT	GPH
#1	RUL	PASS	0.0444
#2	PUL	PASS	0.0148
#3	DSL	PASS	0.0148

LEAK DETECTOR TEST

COMPLETED

LINE NO	PRODUCT	TYPE	RESULT
1	RUL	ELLD	PASS
2	PUL	ELLD	PASS
3	DSL	ELLD	PASS

LIQUID SENSOR FUNCTIONALITY TEST

NOT PERFORMED

LOCATION	PRODUCT	TYPE	RESULT



CERTIFICATION VERIFICATION

August 30, 2023


Tanks Data
914 E Waterford Street
Wakarusa, IN 46573

Testing Date: 8/30/2023
Wakarusa C Store
Location of Test: 914 E Waterford Street
Wakarusa, IN 46573
Site FID#: 08958
Service Technician: 0
Certified Technician: ADAM WILDER

Midwest ECS has completed the following tests/inspections at the above noted location:

ATG Functionality	
Leak Detector	
Elec Line Leak Detector	X
Product Line Testing	X
Liquid Sensor Functionality	
Spill Bucket	
Containment Hydrostatic Sump	
Overfill Equipment Inspection	
Overfill Alarm	
Vent Valve	
Interstitial	
Non-Volumetric Tank Tightness	
Shear Valve Inspection	

I, Adam Wilder, the certified technician, was present throughout the duration of the testing and/or inspection performed by Midwest ECS at the above address on the above date. I affirm that the testing was done in accordance with Rule 329 IAC 9 and 40CFR Part 80, is accurate based upon the results received and that these forms accurately reflects the results of the testing and/or inspection.

Technician Signature: 

Technician Printed Name: ADAM WILDER

Date & Time: 8/30/2023 @ 9:00AM



INDIANA HOMELAND SECURITY

Underground Storage Tank

ADAM P WILDER
500 SIMS STREET
FRANKFORT, INDIANA



STATE/PERMIT #	ISSUE	EFFECTIVE	EXPIRATION
UC112310	01/30/2023	01/30/2023	01/23/2025

DISCIPLINES

☒ Installation or Retrofitting	☐ Decommissioning Closure
☐ Cathodic Protection	☐ Decommissioning Removal
☐ Testing	

I attest with my signature below, that this technician was present onsite for testing as described above.

Midwest ECS
17437 Carey Road Box 163
Westfield, IN 46074
317-763-8330

Work Order Number: NE-0549
Customer: Tanks Data
Contact: Virendar Kumar
Contact Info: contact@tanksdata.com
Site: 08958-TanksData Wakarusa C Store
Job Location: 914 E Waterford Street Wakarusa IN 46550

Primary Tech: Adam Wilder
Appointment Type: Scheduled
Promised Arrival Time: Today 9:00 AM

Category: TESTING
Task: AN:LINE/LEAK DETECTOR
Description: N/A

Work Done Desc.: N/A

