

314 S WATERFORD
WATERBURY, IN 46
219-362-4637
AUG 28, 2025 17:34

PRESSURE LINE LEAK
TEST RESULTS

Q 1:3 RUL

0.0 GAL/HR RESULTS:

LAST TEST:
AUG 28, 2025 17:33 PASS

NUMBER OF TESTS PASSED : 129

PREV 24 HOURS : 106

SINCE MIDNIGHT :

0.20 GAL/HR RESULTS:

AUG	1	2025	21:33	PASS
JUL	2	2025	21:49	PASS
JUN	18	2025	21:57	PASS
JUN	4	2025	22:51	PASS
MAY	1	2025	21:17	PASS
APR	1	2025	22:38	PASS
MAR	2	2025	3:14	PASS
FEB	2	2025	22:41	PASS
JAN	1	2025	23:30	PASS
DEC	12	2024	23:39	PASS

0.0 GAL/HR RESULTS:

JUN	18	2025	22:16	PASS
DEC	16	2024	23:42	PASS
JUN	9	2024	22:48	PASS
DEC	7	2023	1:23	PASS
JUN	5	2023	22:13	PASS
DEC	4	2022	1:24	PASS
JUN	2	2022	22:41	PASS
NOV	29	2021	0:27	PASS
MAY	30	2021	2:13	PASS
OCT	27	2020	0:48	PASS

Q 3:114 PUL

0.0 GAL/HR RESULTS:

LAST TEST:
AUG 28, 2025 17:31 PASS

NUMBER OF TESTS PASSED

PREV 24 HOURS : 162

SINCE MIDNIGHT : 135

0.20 GAL/HR RESULTS:

AUG	1	2025	21:16	PASS
JUL	2	2025	21:14	PASS
JUN	4	2025	5:43	PASS
MAY	1	2025	21:17	PASS
APR	29	2025	22:21	PASS
APR	1	2025	4:15	PASS
MAR	2	2025	3:12	PASS
FEB	2	2025	10:06	PASS
JAN	1	2025	9:36	PASS
DEC	2	2024	21:51	PASS

0.0 GAL/HR RESULTS:

APR	29	2025	23:59	PASS
OCT	27	2024	22:17	PASS
APR	24	2024	23:44	PASS
OCT	23	2023	21:37	PASS
APR	23	2023	0:25	PASS
OCT	20	2022	2:32	PASS
APR	18	2022	0:21	PASS
OCT	17	2021	1:00	PASS
APR	14	2021	16:27	PASS
OCT	12	2020	21:21	PASS

Q 4:126 DSL

0.0 GAL/HR RESULTS:

LAST TEST:
AUG 28, 2025 17:17 PASS

NUMBER OF TESTS PASSED

PREV 24 HOURS : 20

SINCE MIDNIGHT : 19

Q 31114 PUL

5.0 GAL/HR RESULTS:

LAST TEST:
ALG 28, 2025 17:31 PASS
NUMBER OF TESTS PASSED 162
PREV 24 HOURS : 126
SINCE MIDNIGHT :

0.20 GAL/HR RESULTS:

ALG	1, 2025	21:16	PASS
JUL	2, 2025	21:14	PASS
JUN	4, 2025	5:43	PASS
MAY	1, 2025	21:17	PASS
APR	29, 2025	22:21	PASS
APR	1, 2025	4:15	PASS
MAR	2, 2025	3:12	PASS
FEB	2, 2025	10:06	PASS
JAN	1, 2025	9:36	PASS
DEC	2, 2024	21:51	PASS

0.10 GAL/HR RESULTS:

APR	29, 2025	23:59	PASS
OCT	27, 2024	22:17	PASS
APR	24, 2024	23:44	PASS
OCT	23, 2023	21:37	PASS
APR	23, 2023	0:25	PASS
OCT	20, 2022	2:32	PASS
APR	18, 2022	0:21	PASS
OCT	17, 2021	1:00	PASS
APR	14, 2021	16:27	PASS
OCT	12, 2020	21:21	PASS

Q 4:126 DSL

5.0 GAL/HR RESULTS:

LAST TEST:
ALG 28, 2025 17:17 PASS
NUMBER OF TESTS PASSED 20
PREV 24 HOURS : 19
SINCE MIDNIGHT :

0.20 GAL/HR RESULTS:

ALG	1, 2025	8:31	PASS
JUL	2, 2025	9:45	PASS
JUN	2, 2025	8:40	PASS
MAY	3, 2025	12:13	PASS
MAY	1, 2025	12:52	PASS
APR	1, 2025	8:51	PASS
MAR	2, 2025	12:28	PASS
FEB	2, 2025	16:31	PASS
JAN	1, 2025	19:56	PASS
DEC	2, 2024	9:43	PASS

0.10 GAL/HR RESULTS:

ALG	1, 2025	8:31	PASS
ALG	1, 2025	6:54	PASS
JUL	2, 2025	9:45	PASS
JUL	2, 2025	7:10	PASS
JUN	2, 2025	8:40	PASS
JUN	2, 2025	5:03	PASS
MAY	3, 2025	12:13	PASS
MAY	1, 2025	12:52	PASS
MAY	1, 2025	8:40	PASS
APR	1, 2025	8:51	PASS

***** END *****

914 E WATERFORD
WAKARUSA, IN 46573
219-362-4637

ALG 28, 2025 17:34

LIQUID STATUS

ALG 28, 2025 17:34