

914 E WATERFORD
WAKARUSA, IN 46573
219-362-4637

MAY 28, 2025 13:45

LEAK TEST REPORT

2:113 RUL

PROBE SERIAL NUM 571114

TEST STARTING TIME:
MAY 27, 2025 23:30

HEIGHT = 33.6 INCHES
WATER = 0.0 INCHES
TEMP = 58.8 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 3160.7 GAL
PERCENT VOLUME = 31.2

LEAK TEST RESULTS
RATE = 0.05 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST PASS

***** END *****

914 E WATERFORD
WAKARUSA, IN 46573
219-362-4637

MAY 28, 2025 13:45

LEAK TEST REPORT

2:113 RUL

PROBE SERIAL NUM 571116

TEST STARTING TIME:
MAY 27, 2025 23:30

HEIGHT = 35.1 INCHES
WATER = 0.8 INCHES
TEMP = 60.2 F

TEST LENGTH = 2.0 HRS
STRT VOLUME = 2742.6 GAL
PERCENT VOLUME = 33.2

LEAK TEST RESULTS
RATE = 0.06 GAL/HR
THRS = -0.13 GAL/HR
0.20 GAL/HR TEST PASS

***** END *****

914 E WATERFORD
WAKARUSA, IN 46573
219-362-4637

MAY 28, 2025 13:45

PRESSURE LINE LEAK TEST RESULTS

Q 1:113 RUL

3.0 GAL/HR RESULTS:

LAST TEST:
MAY 28, 2025 13:42 PASS

NUMBER OF TESTS PASSED
PREV 24 HOURS : 120
SINCE MIDNIGHT : 66

0.20 GAL/HR RESULTS:

MAY	1,	2025	21:17	PASS
APR	1,	2025	22:38	PASS
MAR	2,	2025	3:14	PASS
FEB	2,	2025	22:41	PASS
JAN	1,	2025	23:30	PASS
DEC	12,	2024	23:39	PASS
DEC	3,	2024	0:56	PASS
NOV	4,	2024	23:16	PASS
OCT	1,	2024	22:20	PASS
SEP	1,	2024	19:49	PASS

0.10 GAL/HR RESULTS:

DEC	16,	2024	23:42	PASS
JUN	9,	2024	22:48	PASS
DEC	7,	2023	1:23	PASS
JUN	5,	2023	22:13	PASS
DEC	4,	2022	1:24	PASS
JUN	2,	2022	22:41	PASS
NOV	29,	2021	0:27	PASS
MAY	30,	2021	2:13	PASS
OCT	27,	2020	0:48	PASS
APR	25,	2020	18:13	PASS

Q 3:114 PUL

3.0 GAL/HR RESULTS:

LAST TEST:
MAY 28, 2025 13:44 PASS

NUMBER OF TESTS PASSED
PREV 24 HOURS : 170
SINCE MIDNIGHT : 92

0.20 GAL/HR RESULTS:

MAY	1,	2025	21:17	PASS
APR	29,	2025	22:21	PASS
APR	1,	2025	4:15	PASS
MAR	2,	2025	3:12	PASS
FEB	2,	2025	10:06	PASS
JAN	1,	2025	9:36	PASS
DEC	2,	2024	21:51	PASS
DEC	2,	2024	22:36	PASS
NOV	27,	2024	1:18	PASS
OCT	25,	2024	22:31	PASS

0.10 GAL/HR RESULTS:

APR	29,	2025	23:59	PASS
APR	27,	2024	22:17	PASS
OCT	24,	2024	23:44	PASS
APR	23,	2023	21:37	PASS
OCT	23,	2023	0:25	PASS
APR	23,	2022	2:32	PASS
OCT	20,	2022	0:21	PASS
APR	18,	2022	1:00	PASS
OCT	17,	2021	16:27	PASS
APR	14,	2021	21:21	PASS
OCT	12,	2020	21:21	PASS

0.41126 DSL

0.0 GAL/HR RESULTS:

LAST TEST:

MAY 28, 2025 13:05 PAES

NUMBER OF TESTS PASSED

PREV 24 HOURS : 7

SINCE MIDNIGHT : 4

0.20 GAL/HR RESULTS:

MAY 3, 2025 12:13 PAES

MAY 1, 2025 12:52 PAES

APR 1, 2025 8:51 PAES

MAR 2, 2025 12:28 PAES

FEB 2, 2025 16:31 PAES

JAN 1, 2025 19:56 PAES

DEC 2, 2024 9:43 PAES

NOV 2, 2024 9:56 PAES

OCT 31, 2024 11:29 PAES

OCT 1, 2024 7:41 PAES

0.10 GAL/HR RESULTS:

MAY 3, 2025 12:13 PAES

MAY 1, 2025 12:52 PAES

MAY 1, 2025 8:40 PAES

APR 1, 2025 8:51 PAES

APR 1, 2025 7:29 PAES

MAR 2, 2025 12:28 PAES

MAR 2, 2025 9:35 PAES

FEB 2, 2025 16:31 PAES

FEB 2, 2025 12:33 PAES

JAN 1, 2025 19:56 PAES

***** END *****

914 E WATERFORD

WAKARUSA, IN 46573

219-362-4637

MAY 28, 2025 13:45

LIQUID STATUS

MAY 28, 2025 13:45

NONE

***** END *****

914 E WATERFORD

WAKARUSA, IN 46573

219-362-4637

MAY 28, 2025 13:45

LEAK TEST REPORT

3:114 PUL

PROBE SERIAL NUM 520013

TEST STARTING TIME:

MAY 27, 2025 23:30

HEIGHT = 31.2 INCHES

WATER = 0.0 INCHES

TEMP = 60.5 F

TEST LENGTH = 2.0 HRS

STRT VOLUME = 1658.6 GAL

PERCENT VOLUME = 43.9

LEAK TEST RESULTS

RATE = 0.00 GAL/HR

THRS = -0.13 GAL/HR

0.20 GAL/HR TEST PASS

***** END *****

914 E WATERFORD

WAKARUSA, IN 46573

219-362-4637

MAY 28, 2025 13:45

LEAK TEST REPORT

4:126 DSL

PROBE SERIAL NUM 571115

TEST STARTING TIME:

MAY 26, 2025 23:30

HEIGHT = 30.0 INCHES

WATER = 0.0 INCHES

TEMP = 59.6 F

TEST LENGTH = 2.0 HRS

STRT VOLUME = 1692.5 GAL

PERCENT VOLUME = 27.8

LEAK TEST RESULTS

RATE = 0.02 GAL/HR

THRS = -0.13 GAL/HR

0.20 GAL/HR TEST PASS

***** END *****