

PETROLEUM TESTING SERVICES, LLC
PO BOX 146
YORKTOWN, IN 47396
765-749-5540
EMAIL:petroleumtesting@aol.com

SITE NAME: MARATHON
STREET NAME: 3901 S MAIN ST
CITY,STATE,ZIP: ELKHART, IN 46517
DATE: 12/29/2022 TIME: 3:30P

LINE AND LEAK DETECTOR TEST

PRODUCT	UNL	PREM	DSL	4	5
OPERATING SYSTEM	PR	PR	PR		
STP MODEL	FE	FE	FE		
OPERATING PRESSURE	32	32	32		
TEST PRESSURE	50	50	50		
ISOLATION	BV	BV	BV		
LINE MATERIAL	FLEX	FLEX	FLEX		
BEGINNING LEVEL	0.0660	0.0660	0.0525		
10 MIN	0.0660	0.0660	0.0525		
20 MIN	0.0660	0.0660	0.0525		
30 MIN	0.0660	0.0660	0.0525		
AMOUNT OF CHANGE	0.0000	0.0000	0.0000		
RESULT	PASS	PASS	PASS		
LEAK DETECTOR MODEL	FE	FE	FE		
LEAK DETECTOR MAKE	MLD	MLD	MLD		
OPENING TIME	2	2	2		
PAUSE PRESSURE	18	18	20		
HOLDING PRESSURE	24	20	20		
TYPE OF TEST	3GAL/HR	3GAL/HR	3GAL/HR		
RESULT	PASS	PASS	PASS		

COMMENTS

TECHNICIAN RONNIE BROWN CERTIFICATION UC2017IN12086