

Witap Marathon
Mishawaka Rd
Dunlap IN
S/N 131209

03/07/2024 11:36 AM

SCALO TEST REPORT

RUL 15041.0 GAL
Unleaded

LEAK TEST 0,200 GPH
LEAK THRESHOLD 0,100 GPH
INTERVAL 18,0
VOL QUALIFY 0,0%
TEST STARTED 12:12 AM
TEST STARTED 03/07/2024
STATUS 0,02
TEST ENDED 2:21 AM
TEST ENDED 03/07/2024

SLOPE -0,062 GAL/HR
TEST RESULT PASSED
SLOPE EQUALS CALCULATED
LEAK RATE

PREM 7099,0 GAL
Premium

LEAK TEST 0,200 GPH
LEAK THRESHOLD 0,100 GPH
INTERVAL 18,0
VOL QUALIFY 0,0%
TEST STARTED 6:03 AM
TEST STARTED 03/07/2024
STATUS 0,02
TEST ENDED 8:08 AM
TEST ENDED 03/07/2024

SLOPE -0,003 GAL/HR
TEST RESULT PASSED
SLOPE EQUALS CALCULATED
LEAK RATE

DSL 7899,0 GAL
Diesel

LEAK TEST 0,200 GPH
LEAK THRESHOLD 0,100 GPH
INTERVAL 18,0
VOL QUALIFY 0,0%
TEST STARTED 6:42 AM
TEST STARTED 03/07/2024
STATUS 0,02
TEST ENDED 8:44 AM
TEST ENDED 03/07/2024

SLOPE -0,006 GAL/HR
TEST RESULT PASSED
SLOPE EQUALS CALCULATED
LEAK RATE