

Dunlap Marathon
Mishawaka Rd
Dunlap IN
S/N 131209

07/14/2024 6:46 PM

LEAK TEST REPORT

RUL 15041,0 GAL

Unleaded

END TIME 9:46 AM
END DATE 03/25/2022
TEST RESULT ABORTED
REASON DISPENSE

PREM 7099,0 GAL

Premium

END TIME 9:53 AM
END DATE 03/25/2022
TEST RESULT ABORTED
REASON DISPENSE

DSL 7899,0 GAL

Diesel

END TIME 9:47 AM
END DATE 03/25/2022
TEST RESULT ABORTED
REASON MINIMUM LEVEL

Dunlap Marathon
Mishawaka Rd
Dunlap IN
S/N 131209

07/14/2024 6:46 PM

SCALD TEST REPORT

RUL 15041,0 GAL

Unleaded

LEAK TEST 0,200 GPH
LEAK THRESHOLD 0,100 GPH
INTERVAL 18,0
VOL QUALIFY 0,0%
TEST STARTED 6:13 AM
TEST STARTED 07/11/2024
STATUS 0,02
TEST ENDED 12:15 AM
TEST ENDED 07/12/2024

SLOPE -0,077 GAL/HR
TEST RESULT PASSED
SLOPE EQUALS CALCULATED
LEAK RATE

PREM 7099,0 GAL

Premium

LEAK TEST 0,200 GPH
LEAK THRESHOLD 0,100 GPH
INTERVAL 18,0
VOL QUALIFY 0,0%
TEST STARTED 11:32 AM
TEST STARTED 07/14/2024
STATUS 0,02
TEST ENDED 2:07 PM
TEST ENDED 07/14/2024

SLOPE -0,017 GAL/HR
TEST RESULT PASSED
SLOPE EQUALS CALCULATED
LEAK RATE

DSL 7899,0 GAL

Diesel

LEAK TEST 0,200 GPH
LEAK THRESHOLD 0,100 GPH
INTERVAL 18,0
VOL QUALIFY 0,0%
TEST STARTED 1:13 PM
TEST STARTED 07/14/2024
STATUS 0,02
TEST ENDED 3:25 PM
TEST ENDED 07/14/2024

SLOPE -0,009 GAL/HR
TEST RESULT PASSED
SLOPE EQUALS CALCULATED
LEAK RATE