

Tanks Data

30 DAYS WALK THROUGH INSPECTION

UST Facility I.D. (FID) #

18662

Contact Number

Facility Name

MARA THER

Contact email

Address

3901 S Main St, Phoenix, AZ

Date of Inspection

10/6/2017

Operator on Duty Name

Y6516

Name of the Person Conducting Inspection

AKSHIT

Operator Training current

Operator Training

Operator Notified

☒ Yes

☐ No

Is Registration current with correct owner, operator etc.

Registration/Notification Form

Operator Notified

☐ Yes

☐ No

Release Detection Method

Release Detection

☒ ATG

☒ IIC

☐ Other

Make and Model

FFS T51001

☐ SIR

☐ IIC

☐ Other

Does it have paper?

☒ Yes

Operator Notified

☒ Yes

☐ No

Is it in Alarm mode?

☒ Yes

Operator Notified

☒ Yes

☐ No

Interstitial Monitoring Sensor Status Normal

☒ Yes

Operator Notified

☒ Yes

☐ No

Necessary Monthly Printout Taken

☒ Yes

Operator Notified

☒ Yes

☐ No

Spill Buckets

☒ Yes

Operator Notified

☒ Yes

☐ No

☒ Yes

Operator Notified

☒ Yes

☐ No

Are Spill Buckets Clean and free from water, debris, product etc?

☒ Yes

Operator Notified

☒ Yes

☐ No

Are the Spill Bucket in good condition and free of damage/cracks

☒ Yes

Operator Notified

☒ Yes

☐ No

Is Fill pipe cap tight and fill pipe free from any obstruction?

☒ Yes

Operator Notified

☒ Yes

☐ No

Pipeline/STP Sumps

☒ Yes

Operator Notified

☒ Yes

☐ No

Are Sumps Clean and free from water, debris, product etc?

☒ Yes

Operator Notified

☒ Yes

☐ No

Under Dispenser Containments (UDC)

☒ Yes

Operator Notified

☒ Yes

☐ No

Are UDCs clean and free from water, debris, product etc?

☒ Yes

Operator Notified

☒ Yes

☐ No

NOTE: ALL LIQUID/DEBRIS OR WASTE MUST BE DISPOSED OFF ACCORDING TO EXISTING RULES AND REGULATIONS

FOLLOWING PROPER PROCEDURE BY A CERTIFIED CONTRACTOR.

Operator on Duty Name

Signature

Date

317-645-0215

tanksdata@gmail.com

www.tanksdata.com

20220516