

Dunlap Marathon
Mishawka Rd
Dunlap IN
S/N 131209

06/09/2024 4:08 PM

LEAK TEST REPORT

RUL 15041.0 GAL

Unleaded

END TIME 9:46 AM
END DATE 03/25/2022
TEST RESULT ABORTED
REASON DISPENSE

PREM 7099.0 GAL

Premium

END TIME 9:53 AM
END DATE 03/25/2022
TEST RESULT ABORTED
REASON DISPENSE

DSL 7899.0 GAL

Diesel

END TIME 9:47 AM
END DATE 03/25/2022
TEST RESULT ABORTED
REASON MINIMUM LEVEL

Dunlap Marathon
Mishawka Rd
Dunlap IN
S/N 131209

06/09/2024 4:09 PM

SCALD TEST REPORT

RUL 15041,0 GAL
Unleaded

LEAK TEST 0,200 GPH
LEAK THRESHOLD 0,100 GPH
INTERVAL 18,0
VOL QUALIFY 0,0%
TEST STARTED 4:12 AM
TEST STARTED 06/09/2024
STATUS 0,02
TEST ENDED 6:22 AM
TEST ENDED 06/09/2024

SLOPE -0,037 GAL/HR
TEST RESULT PASSED
SLOPE EQUALS CALCULATED
LEAK RATE

PREM 7099,0 GAL
Premium

LEAK TEST 0,200 GPH
LEAK THRESHOLD 0,100 GPH
INTERVAL 18,0
VOL QUALIFY 0,0%
TEST STARTED 12:09 PM
TEST STARTED 06/09/2024
STATUS 0,02
TEST ENDED 3:28 PM
TEST ENDED 06/09/2024

SLOPE 0,005 GAL/HR
TEST RESULT PASSED
SLOPE EQUALS CALCULATED
LEAK RATE

DSL 7899,0 GAL
Diesel

LEAK TEST 0,200 GPH
LEAK THRESHOLD 0,100 GPH
INTERVAL 18,0
VOL QUALIFY 0,0%
TEST STARTED 1:14 PM
TEST STARTED 06/09/2024
STATUS 0,02
TEST ENDED 3:17 PM
TEST ENDED 06/09/2024

SLOPE -0,010 GAL/HR
TEST RESULT PASSED
SLOPE EQUALS CALCULATED
LEAK RATE